

CLIPPER STATION 62144, United Kingdom

WMO: 995940

Lat: 53.400N

Lon: 1.700E

Elev: 30

StdP: 100.97

Time Zone: 0.00 (EUW)

Period: 02-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	0.6	1.5	N/A	N/A	N/A	N/A	N/A	N/A	19.7	6.7	17.7	7.1	8.2	60	0.754

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.9	20.2	N/A	19.3	N/A	18.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.0	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.7	14.8	13.4	DB	-0.1	23.3	1.2	1.4	-0.9	24.3	-1.7	25.1	-2.3	25.9	-3.2	27.0	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)			
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.7	5.9	5.2	6.2	8.4	10.9	13.6	16.2	16.5	15.2	12.5	10.1	7.2	(6)	
(7)		DBStd	4.42	1.96	2.07	2.29	2.19	2.02	2.07	1.85	1.49	1.70	1.97	1.84	2.19	(7)	
(8)		HDD10.0	566	127	136	117	57	14	1	0	0	0	4	21	91	(8)	
(9)		HDD18.3	2799	385	369	375	298	231	143	71	58	94	180	248	347	(9)	
(10)		CDD10.0	818	0	0	1	9	42	108	191	203	157	83	23	2	(10)	
(11)		CDD18.3	7	0	0	0	0	0	0	3	3	1	1	0	0	(11)	
(12)		CDH23.3	1	0	0	0	0	0	0	1	1	0	0	0	0	(12)	
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14)	Wind	WSAvg	6.8	8.5	7.4	7.1	6.1	6.3	5.3	5.3	5.6	6.3	7.2	8.1	8.7	(14)	
(15)	Precipitation	PrecAvg	758	73	56	52	46	51	58	61	67	60	71	82	79	(15)	
(16)		PrecMax	902	124	95	96	126	123	143	99	138	122	115	125	128	(16)	
(17)		PrecMin	527	16	18	8	4	14	13	28	10	17	19	36	37	(17)	
(18)		PrecStd	105	30	20	24	31	24	35	23	29	27	24	24	26	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.3	10.2	11.7	15.5	16.7	19.7	22.1	21.6	20.0	19.0	15.0	12.6	(19)	
(20)			MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(20)
(21)		2%	DB	10.0	9.2	10.6	13.4	15.1	17.9	20.4	20.1	19.1	16.7	14.0	11.6	(21)	
(22)			MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(22)
(23)		5%	DB	9.2	8.5	9.8	12.2	14.1	16.9	19.4	19.2	18.3	15.6	13.2	10.9	(23)	
(24)			MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(24)
(25)		10%	DB	8.5	7.8	9.0	11.1	13.3	16.1	18.6	18.6	17.6	14.8	12.5	10.2	(25)	
(26)			MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(27)	
(28)			MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(28)
(29)		2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(29)
(30)			MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(30)
(31)		5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(31)
(32)			MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(32)
(33)		10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(33)
(34)			MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(34)
(35)	Mean Daily Temperature Range	MDBR		2.6	2.5	2.9	3.1	3.1	3.2	3.5	2.9	2.7	2.5	2.4	2.5	(35)	
(36)		5% DB	MCDBR	3.2	2.9	3.8	4.7	4.3	4.8	4.8	3.9	3.7	3.4	2.9	2.9	(36)	
(37)			MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(37)
(38)		5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(38)
(39)			MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.331	0.347	0.377	0.402	0.398	0.405	0.408	0.397	0.381	0.359	0.333	0.318	(40)	
(41)		taud		2.340	2.376	2.315	2.278	2.363	2.357	2.359	2.401	2.434	2.444	2.387	2.321	(41)	
(42)		Ebn at Noon		632	750	800	827	851	847	837	825	792	727	627	568	(42)	
(43)		Edh at Noon		60	78	101	118	114	116	114	104	89	72	57	51	(43)	
(44)	All-Sky Solar Radiation	RadAvg		0.64	1.34	2.60	4.17	5.24	5.43	5.25	4.45	3.16	1.75	0.80	0.50	(44)	
(45)		RadStd		0.06	0.20	0.22	0.40	0.39	0.35	0.45	0.30	0.26	0.12	0.07	0.05	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (43 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page