

K2 BUOY 62081, United KingdomWMO: **996050**Lat: **51.000N**Lon: **13.300W**Elev: **0**StdP: **14.70**Time Zone: **0.00 (EUW)**Period: **01-18**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	42.6	44.0	30.5	24.7	45.0	32.6	27.1	45.8	43.9	47.9	41.1	48.4	24.0	280	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.5	64.3	62.2	63.4	61.4	62.7	60.7	63.1	63.7	62.1	62.9	61.4	62.4	15.1	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.8	85.4	63.6	61.8	82.4	62.8	60.9	79.9	62.2	28.6	64.0	27.9	63.1	27.4	62.5	67.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 38.7	34.6	32.0	DB	39.8	65.1	2.6	2.1	38.0	66.6	36.5	67.8	35.0	69.0	33.2	70.5	(4)
(5)			WB	37.0	63.8	1.7	1.6	35.8	64.9	34.8	65.9	33.8	66.8	32.6	68.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	54.4	50.6	49.9	50.1	51.5	53.1	56.7	59.2	60.0	59.5	56.9	53.3	51.3	(6)
(7)		DBStd	4.50	2.87	2.93	2.97	2.58	2.11	2.36	2.17	1.60	1.96	2.62	2.79	3.11	(7)
(8)		HDD50	135	27	34	31	11	2	0	0	0	0	0	7	23	(8)
(9)		HDD65	3883	447	423	462	405	368	249	181	154	166	252	352	424	(9)
(10)		CDD50	1726	45	31	34	57	99	201	284	311	284	213	104	63	(10)
(11)		CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	18.0	22.8	20.8	20.0	16.1	16.5	14.7	13.7	15.5	16.6	18.9	18.2	22.1	(14)
(15)	Precipitation	PrecAvg	45.1	5.0	4.2	3.5	2.7	2.6	2.6	3.0	3.3	3.6	4.8	4.7	5.2	(15)
(16)		PrecMax	54.0	7.9	8.3	5.3	4.4	5.5	4.0	5.2	6.3	6.7	8.7	7.8	9.7	(16)
(17)		PrecMin	34.8	1.1	1.3	1.6	1.1	1.1	1.1	1.5	1.4	1.2	1.5	2.9	2.1	(17)
(18)		PrecStd	4.3	1.6	1.7	0.9	0.9	0.9	0.7	1.0	1.1	1.3	1.7	1.4	1.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.5	58.1	61.3	67.5	59.0	62.6	65.8	64.9	64.4	62.8	60.1	59.1	(19)
(20)			MCWB	56.8	56.4	58.9	64.4	56.4	60.1	63.6	62.9	62.4	61.2	57.5	57.0	(20)
(21)		2%	DB	57.1	56.1	58.4	58.6	57.4	61.2	64.3	63.9	63.6	61.9	58.7	57.5	(21)
(22)			MCWB	55.5	54.2	56.8	56.8	55.1	58.7	62.0	62.0	61.7	60.1	56.4	55.4	(22)
(23)		5%	DB	55.5	54.3	54.5	55.7	56.7	60.4	63.2	63.0	63.0	61.1	57.9	56.1	(23)
(24)			MCWB	53.7	52.3	52.2	53.7	54.5	58.0	61.1	60.9	61.1	59.0	55.6	54.0	(24)
(25)		10%	DB	54.5	53.6	53.4	54.5	55.9	59.5	62.2	62.4	62.5	60.5	57.1	55.2	(25)
(26)			MCWB	52.5	51.5	51.2	52.2	53.8	57.4	60.2	60.1	60.5	58.1	54.8	53.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.4	56.7	59.1	64.0	57.6	61.9	64.5	63.9	63.8	61.9	58.5	57.9	(27)
(28)			MCDWB	58.2	57.9	60.2	67.6	58.5	62.6	65.3	64.1	63.9	62.2	59.2	58.6	(28)
(29)		2%	WB	55.7	54.5	56.9	57.2	55.8	59.7	62.9	62.9	62.4	60.9	57.4	56.0	(29)
(30)			MCDWB	56.7	55.7	58.5	58.7	56.6	60.5	63.6	63.5	63.0	61.7	58.2	56.9	(30)
(31)		5%	WB	54.1	52.9	53.0	54.3	55.2	58.8	61.8	61.9	61.8	59.7	56.5	54.7	(31)
(32)			MCDWB	55.0	54.0	54.0	55.5	56.1	59.8	62.7	62.7	62.6	60.7	57.5	55.7	(32)
(33)		10%	WB	53.1	52.0	52.0	53.0	54.6	58.0	60.8	61.0	61.1	58.8	55.4	53.7	(33)
(34)			MCDWB	54.2	53.5	53.3	54.4	55.7	59.3	62.0	62.0	62.2	60.1	56.8	55.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.3	3.8	3.8	3.2	2.6	2.9	2.6	2.5	2.7	3.1	3.8	4.2	(35)
(36)			MCDBR	5.5	4.8	5.3	4.8	2.8	4.8	3.9	2.9	2.8	3.0	3.9	5.0	(36)
(37)			MCWBR	7.4	6.4	7.1	6.0	3.6	5.0	3.8	4.3	4.4	4.1	5.5	6.6	(37)
(38)		5% WB	MCDBR	5.2	4.5	5.3	4.8	2.7	4.2	2.9	3.1	2.9	2.9	4.0	5.1	(38)
(39)			MCWBR	7.2	6.3	7.1	6.2	3.4	5.0	4.0	4.7	4.6	4.4	6.0	6.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.365	0.367	0.384	0.385	0.395	0.376	0.380	0.370	0.369	0.364	0.354	0.360	(40)	
(41)		taud	2.221	2.305	2.310	2.360	2.375	2.467	2.467	2.507	2.492	2.409	2.284	2.189	(41)	
(42)		Ebn at Noon	196	237	256	272	273	279	276	274	261	236	200	174	(42)	
(43)		Edh at Noon	24	28	33	35	36	33	33	30	28	25	22	21	(43)	
(44)	All-Sky Solar Radiation	RadAvg	254	467	854	1353	1631	1769	1619	1417	1044	615	309	191	(44)	
(45)		RadStd	24	38	62	83	98	165	135	99	77	42	27	14	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page