

K3 BUOY 62108, United Kingdom

WMO: 996110

Lat: 53.500N

Lon: 19.500W

Elev: 0

StdP: 14.70

Time Zone: 0.00 (EUW)

Period: 94-08

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	39.7	41.5	28.1	22.0	47.6	30.8	25.0	44.9	42.9	45.8	39.7	44.7	23.6	270	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.6	61.9	60.4	61.1	59.7	60.6	59.2	61.0	61.3	60.2	60.7	59.7	60.3	18.9	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.6	79.1	61.1	60.0	77.2	60.6	59.3	75.4	60.2	27.0	61.3	26.6	61.0	26.2	60.5	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 38.9	34.4	31.5	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.1	47.9	48.1	47.6	48.7	51.0	54.0	56.8	58.3	57.3	54.1	51.3	49.6		
	DBStd	4.54	3.22	3.21	3.03	2.63	2.08	1.81	1.85	1.33	2.16	2.63	2.80	3.00		
	HDD50	361	79	67	84	54	14	0	0	0	0	2	18	43		
	HDD65	4714	530	474	539	489	433	331	253	208	230	339	410	478		
	CDD50	1121	14	13	10	14	45	119	212	257	220	128	58	31		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	5	4	1	0	0	0	0	0	0	0	0	0	0		
	CDH80	1	1	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	16.7	21.5	20.2	16.8	13.1	13.7	14.3	14.0	14.7	16.1	18.1	18.9	19.4		
(15) Precipitation	PrecAvg	50.6	5.8	5.0	4.2	2.5	2.5	2.8	3.3	3.5	4.2	5.3	5.1	6.3		
	PrecMax	61.7	9.4	7.9	7.5	5.2	4.4	4.9	4.8	8.0	7.3	9.4	7.9	8.9		
	PrecMin	38.3	0.6	2.6	1.9	1.6	1.2	1.2	2.0	1.8	1.7	1.6	2.5	3.0		
	PrecStd	5.2	1.8	1.7	1.1	0.8	0.7	0.9	0.7	1.5	1.5	1.9	1.3	1.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.8	54.7	53.9	53.9	56.6	61.0	61.9	62.1	63.0	61.0	58.5	57.0		
		MCWB	52.8	52.9	52.0	51.7	55.9	60.6	60.1	60.5	61.0	59.3	57.1	54.4		
	2%	DB	53.9	53.8	53.0	53.1	55.2	58.1	61.0	61.5	62.4	60.1	57.2	55.5		
		MCWB	51.8	52.1	51.2	50.9	54.1	56.8	59.4	60.1	60.8	58.7	55.8	52.8		
	5%	DB	53.2	53.1	52.3	52.7	54.4	57.1	60.3	61.0	61.2	59.1	56.3	54.6		
		MCWB	51.1	51.4	50.6	50.6	53.0	55.9	58.8	59.8	59.6	57.5	54.7	52.0		
	10%	DB	52.5	52.5	51.8	52.1	53.8	56.4	59.6	60.4	60.4	58.0	55.4	53.8		
		MCWB	50.3	50.7	50.1	50.0	52.2	55.0	58.2	59.2	58.7	56.4	53.8	51.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.9	53.7	53.0	53.0	56.4	60.6	60.8	61.5	62.1	60.3	57.7	56.1		
		MCDB	55.1	53.9	53.4	53.5	56.6	60.8	61.0	61.6	62.3	60.5	58.1	56.5		
	2%	WB	53.0	52.8	52.0	52.1	54.6	57.5	60.0	60.9	61.1	59.2	56.4	54.5		
		MCDB	53.7	53.3	52.5	53.0	54.9	57.8	60.4	61.0	61.8	59.9	57.0	55.1		
	5%	WB	52.0	52.1	51.2	51.3	53.6	56.5	59.4	60.2	60.2	58.0	55.5	53.6		
		MCDB	53.1	53.0	52.0	52.4	53.9	56.9	59.9	60.5	61.1	58.8	56.1	54.5		
	10%	WB	51.1	51.1	50.5	50.4	52.8	55.6	58.8	59.8	59.4	56.8	54.5	52.4		
		MCDB	52.5	52.3	51.5	51.8	53.5	56.1	59.4	60.2	60.4	57.7	55.3	53.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.4	5.3	4.5	3.5	2.8	2.5	2.5	2.6	2.9	3.6	4.1	4.9		
		MCDBR	6.8	6.2	5.1	3.5	2.9	2.8	2.8	2.9	3.2	4.5	4.2	5.8		
	5% WB	MCWBR	8.0	7.3	5.7	4.6	3.4	3.3	3.0	3.7	4.3	5.8	5.7	6.7		
		MCWBR	6.7	6.5	5.2	3.8	2.7	2.8	2.6	2.9	3.0	4.5	4.4	6.4		
(40) Clear-Sky Solar Irradiance	taub		0.351	0.364	0.382	0.400	0.396	0.389	0.390	0.385	0.387	0.368	0.340	0.342		
	taud		2.227	2.283	2.298	2.270	2.344	2.415	2.441	2.450	2.382	2.327	2.281	2.193		
	Ebn at Noon		186	228	252	263	271	273	271	266	248	223	190	161		
	Edh at Noon		21	27	32	38	37	35	33	31	30	25	20	18		
(44) All-Sky Solar Radiation	RadAvg		186	406	750	1241	1529	1585	1475	1274	909	530	240	136		
	RadStd		17	37	53	95	121	102	143	117	62	40	18	10		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page