

K3 BUOY 62108, United Kingdom

WMO: 996110

Lat: 53.500N

Lon: 19.500W

Elev: 0

StdP: 101.33

Time Zone: 0.00 (EUW)

Period: 94-08

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	4.3	5.3	-2.2	3.1	8.6	-0.7	3.6	7.1	19.2	7.7	17.8	7.0	10.5	270	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.5	16.6	15.8	16.2	15.4	15.9	15.1	16.1	16.3	15.7	16.0	15.4	15.7	8.5	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.9	11.3	16.2	15.5	11.0	15.9	15.2	10.8	15.7	45.0	16.3	44.0	16.1	43.1	15.8	24.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.4	15.4	14.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.2	8.8	8.9	8.7	9.3	10.6	12.2	13.8	14.6	14.1	12.3	10.7	9.8
	DBStd	2.52	1.79	1.78	1.68	1.46	1.16	1.01	1.03	0.74	1.20	1.46	1.55	1.66
	HDD10.0	201	44	37	47	30	8	0	0	0	0	1	10	24
	HDD18.3	2619	294	263	299	272	241	184	141	116	128	188	228	266
	CDD10.0	623	8	7	6	8	25	66	118	143	122	71	32	17
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	3	2	1	0	0	0	0	0	0	0	0	0	0
	CDH26.7	1	1	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	7.5	9.6	9.0	7.5	5.8	6.1	6.4	6.3	6.6	7.2	8.1	8.4	8.7
Precipitation	PrecAvg	1284	148	127	107	64	63	71	83	90	107	135	130	159
	PrecMax	1567	238	200	191	131	111	124	123	202	186	240	201	226
	PrecMin	973	16	65	47	40	30	30	51	46	44	41	63	75
	PrecStd	132	46	42	29	20	17	22	19	37	38	48	34	40
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.7	12.6	12.1	12.2	13.7	16.1	16.6	16.7	17.2	16.1	14.7	13.9
		MCWB	11.5	11.6	11.1	11.0	13.3	15.9	15.6	15.8	16.1	15.1	13.9	12.4
	2%	DB	12.1	12.1	11.7	11.7	12.9	14.5	16.1	16.4	16.9	15.6	14.0	13.1
		MCWB	11.0	11.1	10.7	10.5	12.3	13.8	15.2	15.6	16.0	14.8	13.2	11.5
	5%	DB	11.8	11.7	11.3	11.5	12.4	13.9	15.7	16.1	16.2	15.0	13.5	12.6
		MCWB	10.6	10.8	10.3	10.3	11.7	13.3	14.9	15.5	15.4	14.2	12.6	11.1
	10%	DB	11.4	11.4	11.0	11.2	12.1	13.6	15.3	15.8	15.8	14.4	13.0	12.1
		MCWB	10.2	10.4	10.1	10.0	11.2	12.8	14.5	15.1	14.8	13.6	12.1	10.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.2	12.1	11.7	11.7	13.6	15.9	16.0	16.4	16.7	15.7	14.3	13.4
		MCDB	12.8	12.2	11.9	12.0	13.7	16.0	16.1	16.4	16.8	15.8	14.5	13.6
	2%	WB	11.6	11.6	11.1	11.2	12.5	14.2	15.6	16.0	16.1	15.1	13.6	12.5
		MCDB	12.0	11.9	11.4	11.7	12.7	14.3	15.8	16.1	16.5	15.5	13.9	12.8
	5%	WB	11.1	11.2	10.7	10.7	12.0	13.6	15.2	15.7	15.7	14.5	13.0	12.0
		MCDB	11.7	11.6	11.1	11.4	12.2	13.8	15.5	15.9	16.2	14.9	13.4	12.5
	10%	WB	10.6	10.6	10.3	10.2	11.5	13.1	14.9	15.4	15.2	13.8	12.5	11.3
		MCDB	11.4	11.3	10.8	11.0	12.0	13.4	15.2	15.7	15.8	14.3	13.0	11.9
Mean Daily Temperature Range	5% DB	MDBR	3.0	3.0	2.5	2.0	1.5	1.4	1.4	1.5	1.6	2.0	2.3	2.7
		MCDBR	3.8	3.4	2.8	1.9	1.6	1.6	1.6	1.6	1.8	2.5	2.3	3.2
		MCWBR	4.5	4.1	3.2	2.6	1.9	1.8	1.6	2.0	2.4	3.2	3.2	3.7
	5% WB	MCDBR	3.7	3.6	2.9	2.1	1.5	1.6	1.5	1.6	1.7	2.5	2.5	3.6
		MCWBR	4.4	4.3	3.4	2.9	2.0	1.9	1.7	2.1	2.4	3.3	3.4	4.4
Clear-Sky Solar Irradiance	taub	0.351	0.364	0.382	0.400	0.396	0.389	0.390	0.385	0.387	0.368	0.340	0.342	
	taud	2.227	2.283	2.298	2.270	2.344	2.415	2.441	2.450	2.382	2.327	2.281	2.193	
	Ebn at Noon	585	718	793	828	853	862	854	837	781	704	598	509	
	Edh at Noon	66	85	102	119	116	110	105	99	94	80	62	57	
All-Sky Solar Radiation	RadAvg	0.58	1.28	2.36	3.91	4.82	5.00	4.65	4.02	2.87	1.67	0.76	0.43	
	RadStd	0.05	0.12	0.17	0.30	0.38	0.32	0.45	0.37	0.20	0.12	0.06	0.03	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page