

NORTH NOMAD BUOY 46184, Canada

WMO: 996210

Lat: 53.910N

Lon: 138.850W

Elev: 10

StdP: 14.69

Time Zone: -9.00 (W09)

Period: 01-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	30.9	33.5	N/A	N/A	N/A	N/A	N/A	N/A	41.1	37.5	39.1	37.9	21.8	10	0.900

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.0	60.4	N/A	59.7	N/A	58.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	15.0	180

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
37.7	34.4	31.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	46.7	41.4	40.6	38.9	41.4	44.9	49.1	53.2	56.2	55.0	50.7	45.5	42.6
	DBStd	6.44	3.61	2.92	2.98	1.92	2.47	2.65	2.44	2.18	2.21	2.80	4.05	3.32
	HDD50	1738	267	264	343	259	160	47	2	0	0	25	140	231
	HDD65	6696	732	684	808	709	624	476	366	273	301	443	585	695
	CDD50	516	0	0	0	0	0	21	101	192	149	48	5	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	17.3	20.5	20.0	17.8	16.3	14.7	13.1	13.1	14.1	17.1	19.1	21.0	20.7
Precipitation	PrecAvg	50.9	5.9	4.6	3.8	2.8	2.4	2.4	2.9	3.3	5.0	6.1	5.4	6.2
	PrecMax	58.0	10.0	8.5	6.3	4.7	3.8	3.7	5.1	5.4	8.1	8.4	7.6	9.7
	PrecMin	43.5	3.0	1.9	2.1	1.0	1.1	1.4	1.0	1.1	2.8	2.6	2.8	3.9
	PrecStd	4.2	1.7	1.5	1.3	0.8	0.7	0.7	0.9	0.9	1.3	1.2	1.5	1.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.7	47.6	45.0	45.9	51.3	58.2	59.0	61.5	61.4	57.6	54.8	51.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	47.7	46.5	44.0	45.3	50.3	55.7	58.1	60.7	60.3	56.4	53.3	49.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	46.8	45.5	43.4	44.8	49.4	54.0	57.4	60.1	59.4	55.5	51.8	47.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	45.9	44.6	42.7	44.1	48.3	52.8	56.7	59.4	58.3	54.6	50.5	46.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Mean Daily Temperature Range	5% DB	MDBR	3.6	3.3	3.5	2.6	2.1	2.1	2.1	2.0	2.5	2.9	3.7	3.8
		MCDBR	3.0	3.1	3.2	2.6	2.3	2.8	2.3	2.2	2.7	2.9	3.2	3.6
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.324	0.332	0.355	0.399	0.403	0.375	0.383	0.388	0.387	0.364	0.330	0.311	
	taud	2.317	2.411	2.354	2.222	2.273	2.442	2.470	2.447	2.366	2.320	2.277	2.273	
	Ebn at Noon	199	243	261	262	268	277	273	264	247	223	190	176	
	Edh at Noon	19	23	30	39	39	34	32	31	30	25	19	16	
All-Sky Solar Radiation	RadAvg	176	398	804	1226	1450	1530	1295	1151	901	503	244	139	
	RadStd	15	46	44	69	104	114	115	98	70	47	20	13	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page