

FAIRWEATHER GROUND BUOY 46083, USA

WMO: 996220

Lat: 58.300N

Lon: 137.997W

Elev: 0

StdP: 101.33

Time Zone: -9.00 (W09)

Period: 02-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	-4.4	-2.4	-10.1	1.6	-2.3	-8.4	1.8	-0.4	19.7	3.3	18.3	3.2	10.6	130	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.4	16.4	14.6	15.5	14.2	15.0	13.9	15.2	15.7	14.7	15.2	14.1	14.6	4.1	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.0	10.6	15.3	14.3	10.2	14.8	13.8	9.8	14.4	42.4	15.8	40.8	15.2	39.3	14.8	18.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.2	16.8	15.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.5	3.4	3.7	3.0	4.9	7.4	10.4	12.8	13.6	11.9	9.0	5.6	4.2	
	DBStd	4.17	2.79	2.05	2.22	1.56	1.64	1.52	1.36	1.25	1.18	1.55	2.22	2.20	
	HDD10.0	1192	204	176	217	154	82	12	0	0	1	37	131	179	
	HDD18.3	3950	462	409	476	404	339	238	173	148	194	289	381	437	
	CDD10.0	284	0	0	0	0	2	24	86	111	57	6	0	0	
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	7.1	9.3	8.0	7.9	6.6	5.6	5.2	4.9	5.0	6.6	7.7	9.2	9.3	
Precipitation	PrecAvg	2589	264	215	190	138	124	94	132	214	309	341	277	292	
	PrecMax	3763	560	401	501	242	247	175	232	390	584	586	464	555	
	PrecMin	2037	59	42	47	22	31	31	47	35	83	108	61	168	
	PrecStd	408	105	95	95	57	60	37	47	90	91	103	97	106	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.0	8.8	7.8	10.1	12.4	15.1	16.6	18.2	15.4	13.0	10.4	9.1	
		MCWB	7.3	5.2	5.4	7.0	10.1	13.4	14.4	15.8	12.9	10.4	7.6	6.4	
	2%	DB	7.7	7.4	6.7	8.6	11.2	14.0	15.6	16.9	14.7	11.8	9.6	8.5	
		MCWB	6.0	5.1	4.7	6.3	9.3	12.9	14.3	15.2	12.8	10.0	7.7	6.4	
	5%	DB	7.0	6.8	6.2	7.7	10.2	13.4	15.1	16.1	14.1	11.3	9.0	7.8	
		MCWB	5.5	5.1	4.4	5.9	8.4	12.1	14.1	14.6	12.7	9.6	7.1	5.8	
	10%	DB	6.4	6.2	5.6	6.9	9.5	12.7	14.6	15.4	13.7	10.9	8.4	7.1	
		MCWB	5.3	5.0	4.0	5.3	7.9	11.2	13.6	14.2	12.2	9.2	6.6	5.4	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.9	6.4	6.3	7.7	11.1	13.5	15.3	16.7	14.3	11.6	9.1	7.8
			MCDB	8.8	6.5	6.4	9.2	12.3	14.6	15.4	18.3	14.3	12.0	9.7	8.3
2%		WB	6.7	6.0	5.4	6.8	9.9	12.3	14.9	15.6	13.8	11.0	8.3	6.8	
		MCDB	7.3	6.3	6.1	8.2	10.8	13.2	15.1	16.4	14.0	11.4	9.4	7.5	
5%		WB	6.0	5.6	4.8	6.2	8.7	11.4	14.3	15.0	13.2	10.4	7.5	6.1	
		MCDB	6.6	6.2	5.7	7.5	9.7	12.0	14.7	15.7	13.5	11.0	8.6	6.9	
10%		WB	5.6	5.2	4.3	5.7	8.2	10.6	13.8	14.5	12.5	9.8	6.9	5.5	
		MCDB	6.2	6.0	5.3	6.8	9.2	11.3	14.3	15.2	13.1	10.7	8.2	6.5	
Mean Daily Temperature Range	5% DB	MDBR	2.5	2.3	2.6	2.0	1.8	1.5	1.4	1.4	1.8	2.1	2.6	2.4	
		MCDBR	2.6	2.5	2.5	2.4	2.4	2.1	1.9	1.7	1.8	2.1	2.6	2.6	
		MCWBR	2.1	1.6	2.1	1.5	1.6	1.4	1.6	1.5	1.7	1.9	2.4	2.4	
	5% WB	MCDBR	2.8	2.3	2.5	2.2	2.1	1.4	1.6	1.7	1.8	1.8	2.4	2.8	
		MCWBR	2.6	2.1	2.5	1.7	1.5	1.2	1.5	1.5	1.9	2.0	2.7	2.8	
Clear-Sky Solar Irradiance	taub		0.323	0.306	0.326	0.375	0.389	0.385	0.378	0.376	0.361	0.332	0.301	0.268	
	taud		2.134	2.408	2.384	2.246	2.282	2.356	2.434	2.443	2.434	2.372	2.209	2.143	
	Ebn at Noon		476	741	824	829	842	851	850	825	777	684	509	432	
	Edh at Noon		53	64	86	115	119	113	102	95	82	65	47	36	
All-Sky Solar Radiation	RadAvg		0.36	1.07	2.34	3.86	4.91	5.18	4.46	3.57	2.40	1.24	0.49	0.23	
	RadStd		0.05	0.15	0.25	0.30	0.45	0.36	0.33	0.46	0.36	0.15	0.07	0.03	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	N/A	+1.20	N/A	N/A	N/A	N/A	N/A	N/A	-227	+64	N/A

Nomenclature: See separate page