

SANTA BARBARA BUOY 46053, CA, USA

WMO: 996400

Lat: 34.252N

Lon: 119.853W

Elev: 0

StdP: 101.33

Time Zone: -8.00 (NAP)

Period: 02-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	9.8	10.4	N/A	N/A	N/A	N/A	N/A	N/A	14.7	13.0	14.1	13.0	6.3	300	0.524

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	2.1	21.7	N/A	20.8	N/A	20.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	4.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.2	11.2	10.1	8.5	22.3	1.3	1.2	7.5	23.2	6.8	24.0	6.1	24.7	5.1	25.6		
			DB	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.8	13.9	13.3	12.9	12.9	13.6	15.0	16.1	16.5	17.0	16.9	15.7	13.9
	DBStd	2.11	1.55	1.34	1.33	1.05	1.18	1.24	1.48	1.59	1.95	1.89	1.54	1.38
	HDD10.0	1	0	0	1	0	0	0	0	0	0	0	0	0
	HDD18.3	1310	136	142	168	163	146	100	72	61	51	55	79	137
	CDD10.0	1758	122	92	91	87	113	150	188	201	209	213	171	121
	CDD18.3	27	0	0	0	0	0	1	2	4	10	9	1	0
	CDH23.3	2	0	0	0	0	0	0	0	0	1	1	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	4.5	3.8	4.7	4.8	5.4	5.1	4.4	4.6	4.6	4.4	4.0	3.9	4.2
Precipitation	PrecAvg	589	167	123	97	35	16	2	0	0	1	23	36	98
	PrecMax	862	634	306	370	166	78	13	5	2	7	146	131	276
	PrecMin	240	20	9	0	11	3	0	0	0	0	1	7	13
	PrecStd	197	165	77	106	38	20	3	1	1	2	35	35	78
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.7	17.4	17.5	17.2	17.9	19.9	21.3	21.9	22.9	23.0	20.3	18.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	17.5	16.2	16.1	15.7	16.6	18.1	20.0	20.4	21.9	21.4	19.2	17.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	16.5	15.5	15.3	14.8	15.8	17.2	19.0	19.5	20.9	20.6	18.5	16.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	15.8	15.0	14.7	14.2	15.2	16.7	18.2	18.8	19.8	19.8	17.9	15.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	2.5	2.3	2.4	2.3	2.3	2.2	2.1	2.0	2.1	2.3	2.3	2.2
		MCDBR	3.5	3.0	3.3	3.1	3.1	3.1	2.5	2.4	2.4	3.0	3.1	2.7
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.303	0.317	0.328	0.363	0.376	0.363	0.393	0.372	0.359	0.350	0.309	0.311	
	taud	2.606	2.582	2.550	2.434	2.415	2.453	2.423	2.450	2.498	2.515	2.607	2.594	
	Ebn at Noon	917	938	950	924	909	916	886	903	903	886	901	884	
	Edh at Noon	76	87	97	114	117	113	116	111	101	91	75	73	
All-Sky Solar Radiation	RadAvg	3.09	3.95	5.30	6.59	7.16	7.32	7.06	6.64	5.75	4.45	3.46	2.79	
	RadStd	0.23	0.40	0.35	0.39	0.53	0.36	0.32	0.30	0.28	0.36	0.20	0.23	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (37 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.62	N/A	-1.64	+0.71	N/A	N/A	N/A	-129	+225	+88

Nomenclature: See separate page