

SANDETTIE LIGHT BUOY 6230, France

WMO: 996480

Lat: 51.102N

Lon: 1.800E

Elev: 0

StdP: 14.70

Time Zone: 0.00 (EUW)

Period: 01-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	31.5	33.5	21.6	16.2	33.8	24.4	18.5	34.7	53.4	47.7	49.2	48.3	19.6	60	0.880

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.3	68.8	63.8	66.8	63.0	65.6	62.3	65.2	67.3	64.2	65.9	63.2	65.1	12.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.3	90.1	66.2	63.3	87.2	65.4	62.4	84.3	64.7	30.1	67.4	29.3	66.1	28.7	65.2	69.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 45.6	41.2	36.5	DB	27.5	77.0	5.5	4.0	23.6	79.9	20.4	82.3	17.3	84.5	13.3	87.4	(4)
(5)			WB	25.4	68.0	5.3	1.7	21.5	69.2	18.4	70.2	15.4	71.2	11.5	72.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	52.3	43.6	42.7	44.5	48.3	52.6	57.3	61.4	63.1	61.1	56.2	50.8	45.5	(6)
(7)		DBStd	8.10	5.23	4.73	4.02	3.67	3.12	2.92	2.71	2.47	2.71	4.06	4.29	5.39	(7)
(8)		HDD50	866	201	207	172	74	11	0	0	0	0	7	40	154	(8)
(9)		HDD65	4654	662	625	634	502	386	233	117	71	120	274	427	603	(9)
(10)		CDD50	1708	4	2	3	23	90	218	354	405	332	198	63	16	(10)
(11)		CDD65	19	0	0	0	0	0	1	5	11	2	0	0	0	(11)
(12)		CDH74	13	0	0	0	0	0	1	4	8	0	0	0	0	(12)
(13)		CDH80	1	0	0	0	0	0	0	1	0	0	0	0	0	(13)
(14)	Wind	WSAvg	19.1	22.7	21.0	18.8	16.3	17.3	16.3	16.5	17.9	20.3	22.6	23.2	(14)	
(15)	Precipitation	PrecAvg	25.9	2.4	1.9	1.5	1.7	1.9	2.0	1.9	2.2	2.1	3.0	2.6	(15)	
(16)		PrecMax	35.3	5.1	4.1	3.9	4.6	4.3	4.5	3.2	4.6	4.1	7.4	5.6	4.5	(16)
(17)		PrecMin	19.5	0.6	0.3	0.3	0.2	0.3	0.5	0.5	0.4	0.2	0.3	1.1	0.6	(17)
(18)		PrecStd	3.9	1.1	1.1	0.8	1.1	1.0	1.2	0.8	1.3	1.1	1.5	1.3	1.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.4	53.4	55.2	59.4	62.9	69.0	70.7	74.0	69.2	65.7	61.0	57.4	(19)
(20)			MCWB	51.7	49.2	49.4	53.0	55.9	62.2	65.1	66.5	63.2	61.7	57.8	53.4	(20)
(21)		2%	DB	52.8	51.6	51.6	56.3	59.1	63.8	67.5	69.8	67.0	63.9	59.1	55.5	(21)
(22)			MCWB	50.6	49.0	47.9	51.3	54.9	59.7	63.5	64.7	62.8	60.8	56.1	52.5	(22)
(23)		5%	DB	51.6	50.2	50.3	54.1	57.6	61.7	65.8	67.1	65.6	62.8	58.1	54.2	(23)
(24)			MCWB	49.2	47.7	47.3	50.4	54.4	58.4	62.4	63.5	62.3	59.9	55.1	51.3	(24)
(25)		10%	DB	50.4	48.8	49.3	52.5	56.3	60.3	64.6	65.8	64.6	61.6	56.8	52.9	(25)
(26)			MCWB	47.9	46.3	46.7	49.6	53.6	57.5	61.8	62.7	61.7	58.6	53.7	50.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.6	50.3	50.3	54.1	57.9	63.5	65.8	67.9	65.0	62.9	58.8	54.4	(27)
(28)			MCDWB	53.6	52.2	52.8	57.4	60.7	67.0	68.5	73.0	66.4	64.6	60.7	55.9	(28)
(29)		2%	WB	51.3	49.4	49.0	52.3	55.8	60.5	64.5	65.7	64.0	61.6	57.1	53.3	(29)
(30)			MCDWB	52.6	51.2	50.9	54.8	57.7	62.8	66.4	68.1	65.6	63.5	58.8	55.0	(30)
(31)		5%	WB	49.7	48.0	48.0	51.2	54.9	59.2	63.4	64.6	63.3	60.5	55.5	51.9	(31)
(32)			MCDWB	51.2	49.7	49.7	53.5	56.8	61.0	65.3	66.5	65.1	62.6	57.8	54.1	(32)
(33)		10%	WB	48.3	46.7	47.1	50.2	54.1	58.3	62.3	63.6	62.5	59.3	54.0	50.3	(33)
(34)			MCDWB	50.1	48.5	48.9	52.2	56.1	60.0	64.2	65.4	64.5	61.4	56.5	52.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.3	4.8	4.6	4.4	3.9	3.8	4.0	4.3	4.3	5.2	5.3	5.6	(35)
(36)			MCDBR	5.3	5.4	6.1	7.3	6.2	6.6	5.9	6.3	5.4	5.9	6.0	5.8	(36)
(37)			MCWBR	6.4	5.2	5.2	4.7	4.3	5.2	4.0	4.6	4.9	6.0	6.6	6.6	(37)
(38)		5% WB	MCDBR	5.2	5.1	5.5	6.7	5.4	5.8	5.5	6.0	4.8	5.9	6.1	5.6	(38)
(39)			MCWBR	6.5	5.2	5.2	4.7	4.2	5.1	4.2	4.8	4.7	6.3	6.9	6.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.336	0.354	0.392	0.408	0.417	0.416	0.414	0.406	0.386	0.371	0.345	0.328	(40)	
(41)		taud	2.376	2.368	2.265	2.256	2.289	2.310	2.324	2.366	2.411	2.418	2.401	2.364	(41)	
(42)		Ebn at Noon	214	243	253	263	266	267	265	261	254	233	209	196	(42)	
(43)		Edh at Noon	20	26	35	39	40	39	38	35	30	25	20	18	(43)	
(44)	All-Sky Solar Radiation	RadAvg	253	473	849	1369	1618	1784	1699	1426	1062	606	298	195	(44)	
(45)		RadStd	22	74	105	124	117	143	151	108	74	55	33	25	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (73 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page