

W DIXON ENTRANCE BUOY 46205, Canada

WMO: 996490

Lat: 54.160N

Lon: 134.280W

Elev: 3

StdP: 101.29

Time Zone: -9.00 (W09)

Period: 02-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	-2.1	0.1	N/A	N/A	N/A	N/A	N/A	N/A	19.4	5.6	18.1	5.6	8.8	30	0.858

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.3	16.5	N/A	15.9	N/A	15.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.4	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
17.2	15.6	14.2	-2.5	16.0	2.0	1.4	-3.9	16.9	-5.1	17.7	-6.2	18.5	-7.6	19.5		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.9	5.9	5.5	5.2	6.3	8.1	10.5	12.8	14.0	13.2	10.8	7.6	6.3
	DBStd	3.56	2.44	2.04	2.20	1.20	1.37	1.36	1.27	1.25	1.19	1.36	2.24	2.16
	HDD10.0	778	127	126	148	111	61	9	0	0	0	8	74	114
	HDD18.3	3453	386	359	406	361	318	236	173	133	153	235	322	372
	CDD10.0	367	0	0	0	0	2	24	86	125	97	32	2	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	7.5	9.4	8.3	8.3	7.3	6.3	5.6	5.6	5.7	6.9	8.2	9.1	9.1
Precipitation	PrecAvg	1789	209	149	146	111	82	77	81	107	144	219	232	232
	PrecMax	2250	289	244	224	206	177	112	144	179	251	338	393	415
	PrecMin	1436	125	49	71	65	4	47	26	54	64	92	149	136
	PrecStd	197	41	51	39	29	35	20	30	37	43	57	50	67
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.0	10.0	9.6	10.2	11.8	14.7	15.7	17.8	16.6	14.7	12.1	11.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	9.4	9.1	8.8	8.9	10.9	13.7	15.2	17.1	16.0	13.6	11.5	10.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	8.9	8.2	8.2	8.3	10.5	13.1	14.9	16.4	15.5	13.1	10.9	9.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	8.4	7.9	7.7	8.0	10.0	12.4	14.5	15.8	15.0	12.7	10.3	8.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	2.2	2.0	2.2	1.7	1.3	1.2	1.2	1.3	1.5	1.7	2.2	2.1
		MCDBR	1.9	1.9	2.2	1.9	1.5	1.6	1.4	1.5	1.7	2.0	2.0	2.1
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.316	0.322	0.347	0.393	0.387	0.377	0.376	0.380	0.384	0.354	0.321	0.309	
	taud	2.352	2.472	2.410	2.258	2.349	2.437	2.495	2.480	2.390	2.381	2.326	2.283	
	Ebn at Noon	637	781	833	832	859	872	867	840	781	717	616	552	
	Edh at Noon	56	69	90	119	115	107	99	95	92	74	57	49	
All-Sky Solar Radiation	RadAvg	0.52	1.31	2.48	3.92	4.65	5.00	4.32	3.84	2.78	1.55	0.73	0.41	
	RadStd	0.05	0.19	0.23	0.21	0.30	0.38	0.30	0.35	0.26	0.15	0.07	0.05	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+66	N/A

Nomenclature: See separate page