

LA PEROUSE BANK BUOY 46206, Canada

WMO: 996500

Lat: 48.840N

Lon: 126.000W

Elev: 10

StdP: 14.69

Time Zone: -8.00 (W08)

Period: 02-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	35.9	38.2	N/A	N/A	N/A	N/A	N/A	N/A	39.4	45.0	36.6	45.2	16.9	90	0.729

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.5	62.1	N/A	60.9	N/A	60.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	8.4	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
35.4	31.8	28.5	DB	32.8	66.3	3.2	2.9	30.5	68.4	28.6	70.1	26.8	71.8	24.5	73.9	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.5	45.8	45.6	45.4	47.3	51.0	54.5	56.6	56.8	55.8	52.6	48.6	45.9
	DBStd	5.19	3.58	2.64	2.85	2.45	2.70	2.28	2.14	2.00	2.24	2.50	3.34	3.41
	HDD50	703	132	124	144	86	21	0	0	0	0	5	61	130
	HDD65	5285	595	543	608	530	435	314	260	254	275	386	493	592
	CDD50	894	2	2	1	6	51	136	205	211	175	84	18	3
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
(14) Wind	WSAvg	13.6	17.5	15.0	15.6	13.2	11.8	12.1	11.3	9.6	10.4	12.4	16.2	17.7
(15) Precipitation	PrecAvg	124.8	18.9	11.5	12.2	9.4	5.3	4.3	2.7	4.4	5.7	13.2	18.4	18.6
	PrecMax	165.4	34.4	30.9	24.1	18.4	10.4	11.2	9.3	13.7	13.5	21.2	28.1	29.2
	PrecMin	102.5	11.6	2.1	2.5	2.7	1.7	1.3	0.1	0.4	0.7	2.1	7.0	7.3
	PrecStd	16.8	5.9	6.1	4.8	4.5	2.2	2.5	2.2	3.7	3.2	5.8	5.8	4.8
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.8	52.9	52.1	54.9	60.9	63.4	64.2	64.0	63.3	59.3	57.8	54.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	51.8	51.4	51.2	52.9	56.7	59.7	61.8	61.5	61.6	58.2	55.7	52.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	50.9	50.1	50.0	51.8	55.4	58.3	60.3	60.5	60.4	57.1	53.8	51.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	50.1	49.0	49.1	50.7	54.3	57.5	59.4	59.7	59.1	56.2	52.7	50.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	5% DB	MDBR	3.5	3.1	3.7	3.3	2.8	2.9	3.0	3.5	3.7	3.5	3.8	3.7
		MCDBR	3.7	3.2	3.8	3.9	3.8	4.3	4.0	4.4	4.9	4.0	4.3	4.4
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub		0.326	0.327	0.348	0.372	0.387	0.364	0.353	0.356	0.349	0.350	0.333	0.318
	taud		2.460	2.519	2.473	2.392	2.375	2.470	2.541	2.540	2.547	2.490	2.447	2.446
	Ebn at Noon		233	264	275	278	277	285	286	281	272	250	227	219
	Edh at Noon		20	24	29	35	37	34	31	30	27	24	20	18
(44) All-Sky Solar Radiation	RadAvg		282	570	876	1346	1680	1826	1870	1609	1206	675	341	232
	RadStd		36	77	99	118	146	163	148	132	95	86	54	30

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (31 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page