

LA PEROUSE BANK BUOY 46206, Canada

WMO: 996500

Lat: 48.840N

Lon: 126.000W

Elev: 3

StdP: 101.29

Time Zone: -8.00 (W08)

Period: 02-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	2.2	3.5	N/A	N/A	N/A	N/A	N/A	N/A	17.6	7.2	16.4	7.3	7.6	90	0.729

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.9	16.7	N/A	16.1	N/A	15.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	3.7	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
15.8	14.2	12.7	DB	0.5	19.1	1.8	1.6	-0.8	20.2	-1.9	21.2	-2.9	22.1	-4.2	23.3	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.3	7.7	7.6	7.4	8.5	10.5	12.5	13.7	13.8	13.2	11.4	9.2	7.7
	DBStd	2.88	1.99	1.47	1.58	1.36	1.50	1.26	1.19	1.11	1.25	1.39	1.85	1.89
	HDD10.0	391	73	69	80	48	12	0	0	0	0	3	34	72
	HDD18.3	2936	331	302	338	294	242	174	144	141	153	214	274	329
	CDD10.0	497	1	1	1	3	28	76	114	117	97	47	10	2
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	6.1	7.8	6.7	7.0	5.9	5.3	5.4	5.0	4.3	4.6	5.6	7.3	7.9
Precipitation	PrecAvg	3171	480	293	311	239	134	110	69	112	145	336	467	472
	PrecMax	4201	874	786	613	467	264	285	235	347	344	538	715	742
	PrecMin	2604	295	54	63	68	44	33	3	10	18	53	178	185
	PrecStd	427	150	156	122	114	57	64	57	94	82	147	148	122
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.6	11.6	11.2	12.7	16.0	17.4	17.9	17.8	17.4	15.2	14.3	12.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	11.0	10.8	10.7	11.6	13.7	15.4	16.6	16.4	16.4	14.5	13.2	11.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	10.5	10.0	10.0	11.0	13.0	14.6	15.7	15.8	15.8	14.0	12.1	10.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	10.0	9.5	9.5	10.4	12.4	14.2	15.2	15.4	15.1	13.4	11.5	10.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	2.0	1.7	2.0	1.8	1.5	1.6	1.6	1.9	2.1	1.9	2.1	2.0
		MCDBR	2.1	1.8	2.1	2.2	2.1	2.4	2.2	2.5	2.7	2.2	2.4	2.5
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.326	0.327	0.348	0.372	0.387	0.364	0.353	0.356	0.349	0.350	0.333	0.318	
	taud	2.460	2.519	2.473	2.392	2.375	2.470	2.541	2.540	2.547	2.490	2.447	2.446	
	Ebn at Noon	735	832	868	877	874	897	902	885	858	788	715	691	
	Edh at Noon	64	75	92	109	116	106	97	93	84	76	64	57	
All-Sky Solar Radiation	RadAvg	0.89	1.80	2.76	4.24	5.30	5.76	5.90	5.07	3.80	2.13	1.08	0.73	
	RadStd	0.12	0.24	0.31	0.37	0.46	0.51	0.47	0.42	0.30	0.27	0.17	0.10	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(47)	Regional (31 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page