

WEST MORESBY BUOY 46208, CanadaWMO: **996510**Lat: **52.520N**Lon: **132.690W**Elev: **3**StdP: **101.29**Time Zone: **-9.00 (W09)**Period: **01-15**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	-0.6	1.2	N/A	N/A	N/A	N/A	N/A	N/A	19.4	6.2	17.8	6.3	8.6	10	0.845

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.3	16.7	N/A	16.2	N/A	15.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.3	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.1	15.4	13.9	-2.2	16.6	3.3	1.1	-4.6	17.3	-6.5	18.0	-8.3	18.6	-10.7	19.4
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.3	6.4	6.2	5.7	6.7	8.5	10.8	13.0	14.3	13.6	11.2	8.2	6.8
	DBStd	3.44	2.16	1.83	2.03	1.25	1.24	1.34	1.28	1.27	1.06	1.52	2.12	2.10
	HDD10.0	672	112	106	133	101	49	6	0	0	0	7	58	100
	HDD18.3	3299	370	339	392	350	306	226	166	124	142	221	304	358
	CDD10.0	413	0	0	0	0	2	29	92	134	108	43	4	1
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	7.4	8.7	7.9	8.1	7.3	6.6	6.0	5.9	5.6	6.6	7.9	8.8	9.0
Precipitation	PrecAvg	1789	209	149	146	111	82	77	81	107	144	219	232	232
	PrecMax	2250	289	244	224	206	177	112	144	179	251	338	393	415
	PrecMin	1436	125	49	71	65	4	47	26	54	64	92	149	136
	PrecStd	197	41	51	39	29	35	20	30	37	43	57	50	67
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.5	10.2	10.2	11.0	11.6	15.4	16.1	18.1	16.7	15.0	12.6	11.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	9.9	9.6	9.5	9.5	11.0	14.1	15.6	17.4	16.0	14.2	11.9	10.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	9.2	9.0	8.9	8.8	10.6	13.4	15.2	16.7	15.6	13.8	11.3	9.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	8.8	8.4	8.3	8.3	10.2	12.6	14.8	16.2	15.2	13.2	10.8	9.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	2.0	1.8	2.1	1.7	1.3	1.3	1.2	1.3	1.5	1.8	2.2	2.1
		MCDBR	1.8	1.9	1.9	2.2	1.5	1.8	1.4	1.6	1.6	1.9	2.2	2.0
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.323	0.328	0.355	0.394	0.394	0.377	0.378	0.383	0.377	0.356	0.329	0.315	
	taud	2.368	2.462	2.386	2.268	2.330	2.442	2.487	2.477	2.441	2.402	2.336	2.320	
	Ebn at Noon	664	791	833	838	858	876	869	844	802	737	641	595	
	Edh at Noon	60	73	95	120	119	107	101	97	90	76	61	53	
All-Sky Solar Radiation	RadAvg	0.61	1.45	2.57	4.03	4.82	5.06	4.55	4.02	3.02	1.69	0.83	0.51	
	RadStd	0.07	0.22	0.26	0.22	0.29	0.37	0.39	0.31	0.26	0.16	0.08	0.07	

Historical Trends

</
