

WEST SEA OTTER BUOY 46204, Canada

WMO: 996540

Lat: 51.380N

Lon: 128.770W

Elev: 10

StdP: 14.69

Time Zone: -9.00 (W09)

Period: 01-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	30.6	34.2	N/A	N/A	N/A	N/A	N/A	N/A	45.2	43.0	42.5	44.2	20.3	20	0.808

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.6	62.1	N/A	61.2	N/A	60.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	10.7	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 41.7	37.7	33.8	DB	27.2	63.1	6.3	2.8	22.7	65.1	19.0	66.7	15.5	68.3	11.0	70.3	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	49.3	43.8	43.5	43.4	45.5	49.0	53.1	56.5	58.1	55.6	51.4	46.7	44.3
	DBStd	6.04	4.27	3.44	3.64	2.43	2.47	2.39	2.25	2.02	1.84	2.49	3.66	3.70
	HDD50	1063	193	181	204	136	49	3	0	0	0	15	104	178
	HDD65	5738	657	601	668	585	496	358	265	215	281	422	548	642
	CDD50	797	1	0	0	1	18	94	200	250	169	58	5	1
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	16.0	20.3	18.2	18.5	15.3	12.7	12.4	12.2	11.3	13.1	16.3	20.0	21.7
Precipitation	PrecAvg	116.7	13.8	9.8	10.6	8.3	5.5	4.7	4.0	5.3	8.1	14.8	16.7	15.2
	PrecMax	145.8	20.7	16.9	20.6	16.0	11.2	8.1	11.5	11.2	15.0	23.8	23.9	25.7
	PrecMin	93.9	6.7	4.3	4.0	3.4	1.8	1.7	0.9	1.3	1.3	6.7	9.7	6.3
	PrecStd	13.8	3.5	3.3	3.1	2.2	2.0	1.5	2.4	2.2	3.3	4.4	3.9	4.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.3	51.2	51.3	53.1	55.5	61.1	62.4	64.1	61.4	58.3	54.5	52.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	50.4	49.5	49.9	50.8	54.0	58.5	61.1	62.9	60.1	56.6	53.1	50.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	49.4	48.5	48.7	49.7	53.1	57.5	60.3	61.9	59.1	55.6	51.9	49.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	48.5	47.6	47.7	48.7	52.2	56.4	59.7	61.0	58.4	54.8	51.0	48.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	4.0	3.5	3.9	3.3	2.7	2.6	2.4	2.6	3.0	3.3	4.1	4.0
		MCDBR	4.0	3.5	3.6	3.9	3.3	3.4	2.8	3.1	3.3	3.9	4.1	4.3
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.319	0.326	0.348	0.379	0.381	0.372	0.365	0.368	0.364	0.346	0.327	0.313	
	taud	2.441	2.496	2.452	2.353	2.392	2.462	2.522	2.521	2.505	2.488	2.404	2.377	
	Ebn at Noon	223	256	270	273	277	280	280	274	262	244	214	201	
	Edh at Noon	19	23	29	35	36	34	31	30	27	23	19	17	
All-Sky Solar Radiation	RadAvg	213	489	810	1285	1605	1708	1641	1410	1019	565	270	179	
	RadStd	26	79	104	84	139	163	180	157	91	71	35	26	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (14 neighbors)	N/A	N/A	N/A	+0.81	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page