

WEST SEA OTTER BUOY 46204, Canada

WMO: 996540

Lat: 51.380N

Lon: 128.770W

Elev: 3

StdP: 101.29

Time Zone: -9.00 (W09)

Period: 01-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	-0.8	1.2	N/A	N/A	N/A	N/A	N/A	N/A	20.2	6.1	19.0	6.8	9.1	20	0.808

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.4	16.7	N/A	16.2	N/A	15.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	4.8	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.6	16.9	15.1	DB	-2.7	17.3	3.5	1.5	-5.2	18.4	-7.2	19.3	-9.2	20.2	-11.7	21.3	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.6	6.6	6.4	6.4	7.5	9.4	11.7	13.6	14.5	13.1	10.8	8.2	6.8		
	DBStd	3.36	2.37	1.91	2.02	1.35	1.37	1.33	1.25	1.12	1.02	1.38	2.03	2.06		
	HDD10.0	591	107	101	113	76	27	2	0	0	0	8	58	99		
	HDD18.3	3188	365	334	371	325	276	199	147	119	156	234	304	357		
	CDD10.0	443	1	0	0	1	10	52	111	139	94	32	3	1		
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	7.1	9.1	8.1	8.3	6.8	5.7	5.6	5.4	5.0	5.9	7.3	8.9	9.7		
(15) Precipitation	PrecAvg	2965	351	250	268	212	139	120	101	135	205	375	423	387		
	PrecMax	3703	526	430	524	407	284	205	293	284	380	604	607	654		
	PrecMin	2385	170	109	102	87	46	43	22	33	32	169	247	159		
	PrecStd	351	89	83	80	56	51	38	60	57	85	112	99	104		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.8	10.6	10.7	11.7	13.1	16.2	16.9	17.8	16.4	14.6	12.5	11.3		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	10.2	9.7	10.0	10.4	12.2	14.7	16.2	17.2	15.6	13.7	11.7	10.4		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	9.7	9.2	9.3	9.8	11.7	14.1	15.7	16.6	15.1	13.1	11.1	9.8		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	9.2	8.6	8.7	9.3	11.2	13.6	15.4	16.1	14.7	12.7	10.5	9.4		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	2.2	2.0	2.2	1.8	1.5	1.4	1.3	1.4	1.7	1.9	2.3	2.2		
		MCDBR	2.2	1.9	2.0	2.2	1.8	1.9	1.6	1.7	1.9	2.2	2.3	2.4		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.319	0.326	0.348	0.379	0.381	0.372	0.365	0.368	0.364	0.346	0.327	0.313		
	taud		2.441	2.496	2.452	2.353	2.392	2.462	2.522	2.521	2.505	2.488	2.404	2.377		
	Ebn at Noon		702	808	852	860	874	884	884	865	826	769	675	634		
	Edh at Noon		59	73	90	111	112	106	98	94	86	72	60	54		
(44) All-Sky Solar Radiation	RadAvg		0.67	1.54	2.55	4.05	5.06	5.38	5.17	4.44	3.21	1.78	0.85	0.56		
	RadStd		0.08	0.25	0.33	0.27	0.44	0.51	0.57	0.49	0.29	0.22	0.11	0.08		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (14 neighbors)	N/A	N/A	N/A	+0.45	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page