

SOUTH KODIAK BUOY 46066, USA

WMO: 996610

Lat: 52.765N

Lon: 155.009W

Elev: 0

StdP: 14.70

Time Zone: -10.00 (W10)

Period: 02-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	26.5	28.9	N/A	N/A	N/A	N/A	N/A	N/A	42.8	32.5	40.4	33.1	25.2	310	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.8	57.4	N/A	56.7	N/A	55.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	15.1	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 38.5	35.5	32.8	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	43.7	38.3	38.2	36.6	38.3	41.8	45.8	50.3	53.4	52.1	47.4	42.1	39.6		
	DBStd	6.34	3.56	2.92	3.90	2.06	2.29	2.30	2.17	1.91	2.27	2.73	3.35	3.05		
	HDD50	2513	364	330	415	350	253	127	21	0	7	87	236	323		
	HDD65	7775	829	750	880	800	718	576	455	361	386	546	686	788		
	CDD50	214	0	0	0	0	0	1	31	105	71	6	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	18.1	20.5	18.5	20.4	18.7	15.6	13.5	13.9	15.2	18.2	19.9	22.3	21.1		
	PrecAvg	42.2	4.2	3.6	2.8	2.2	2.2	2.4	3.1	3.9	4.4	4.6	3.9	4.8		
	PrecMax	53.1	6.7	5.7	4.6	4.8	3.7	3.9	5.6	7.0	7.1	8.2	6.3	9.2		
(15) Precipitation	PrecMin	33.5	2.4	0.6	1.0	1.1	0.8	1.2	1.4	1.5	3.0	2.3	1.7	2.9		
	PrecStd	4.2	1.1	1.3	0.9	0.8	0.7	0.7	1.0	1.3	1.1	1.4	1.1	1.3		
	DB	45.4	44.3	44.8	43.4	48.1	52.3	56.4	58.4	58.5	54.4	49.5	46.5			
	MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
	2% DB	44.2	42.9	42.3	42.4	46.7	51.0	55.3	57.5	57.4	53.0	48.3	45.6			
(21) Mean Coincident Wet Bulb Temperatures	MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
	5% DB	43.2	42.2	41.5	41.7	45.9	50.1	54.3	57.1	56.4	52.0	47.6	44.5			
	MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
	10% DB	42.2	41.6	41.1	41.3	45.0	49.2	53.3	56.5	55.3	51.1	46.5	43.5			
	MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2% WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(31) Mean Daily Temperature Range	MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10% WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% DB	3.8	3.3	4.0	2.6	1.9	1.8	1.9	1.8	2.2	2.8	3.7	3.5			
	MCDBR	4.6	4.1	4.1	2.5	2.1	2.1	2.2	2.1	2.4	2.9	3.4	3.0			
(36) Clear-Sky Solar Irradiance	MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	taub	0.334	0.347	0.377	0.423	0.403	0.398	0.386	0.397	0.392	0.364	0.341	0.334			
(40) All-Sky Solar Radiation	taud	2.258	2.317	2.224	2.121	2.262	2.351	2.459	2.412	2.332	2.299	2.222	2.191			
	Ebn at Noon	199	238	253	255	269	271	273	263	247	226	191	171			
	Edh at Noon	21	26	35	44	40	37	33	33	31	26	21	19			
(44) All-Sky Solar Radiation	RadAvg	214	438	810	1181	1414	1403	1291	1111	889	554	272	162			
	RadStd	21	30	66	69	132	126	89	108	54	39	24	16			

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page