

SOUTH KODIAK BUOY 46066, USA

WMO: 996610

Lat: 52.765N

Lon: 155.009W

Elev: 0

StdP: 101.33

Time Zone: -10.00 (W10)

Period: 02-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 3	(b) -3.0	(c) -1.7	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 19.1	(k) 0.3	(l) 18.1	(m) 0.6	(n) 11.2	(o) 310	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 1.0	(c) 14.1	(d) N/A	(e) 13.7	(f) N/A	(g) 13.2	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 6.8	(p) 290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 17.2	(b) 15.9	(c) 14.7	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.5	3.5	3.5	2.6	3.5	5.5	7.7	10.2	11.9	11.2	8.6	5.6	4.2
	DBStd	3.52	1.98	1.62	2.17	1.14	1.27	1.28	1.20	1.06	1.26	1.52	1.86	1.69
	HDD10.0	1396	202	183	231	194	141	71	12	0	4	48	131	179
	HDD18.3	4319	461	417	489	444	399	320	253	201	214	303	381	438
	CDD10.0	119	0	0	0	0	0	1	17	58	39	3	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
(14) Wind	WSAvg	8.1	9.2	8.3	9.1	8.4	7.0	6.0	6.2	6.8	8.1	8.9	10.0	9.4
(15) Precipitation	PrecAvg	1072	107	91	71	57	56	60	80	98	112	117	100	122
	PrecMax	1350	169	146	118	122	93	98	141	177	181	208	159	234
	PrecMin	852	60	16	26	27	20	31	36	39	76	58	42	73
	PrecStd	107	29	33	23	20	17	17	25	33	28	36	28	34
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.4	6.8	7.1	6.3	9.0	11.3	13.6	14.7	14.7	12.5	9.7	8.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	6.8	6.0	5.7	5.8	8.2	10.6	12.9	14.1	14.1	11.7	9.0	7.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	6.2	5.7	5.3	5.4	7.7	10.1	12.4	13.9	13.5	11.1	8.7	6.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	5.6	5.3	5.0	5.1	7.2	9.6	11.8	13.6	12.9	10.6	8.0	6.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	5% DB	MDBR	2.1	1.8	2.2	1.4	1.1	1.0	1.0	1.0	1.2	1.6	2.0	2.0
		MCDBR	2.6	2.3	2.3	1.4	1.1	1.2	1.2	1.2	1.3	1.6	1.9	1.7
	5% WB	MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub		0.334	0.347	0.377	0.423	0.403	0.398	0.386	0.397	0.392	0.364	0.341	0.334
	taud		2.258	2.317	2.224	2.121	2.262	2.351	2.459	2.412	2.332	2.299	2.222	2.191
	Ebn at Noon		627	751	799	804	847	855	861	828	779	714	602	538
	Edh at Noon		66	83	111	139	127	117	104	103	99	83	67	59
(44) All-Sky Solar Radiation	RadAvg		0.68	1.38	2.55	3.72	4.46	4.42	4.07	3.50	2.80	1.75	0.86	0.51
	RadStd		0.07	0.10	0.21	0.22	0.41	0.40	0.28	0.34	0.17	0.12	0.08	0.05

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page