

EAST DELLWOOD BUOY 46207, Canada

WMO: 996620

Lat: 50.870N

Lon: 129.920W

Elev: 10

StdP: 14.69

Time Zone: -9.00 (W09)

Period: 01-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	33.8	36.7	N/A	N/A	N/A	N/A	N/A	N/A	44.9	45.0	41.8	44.6	18.6	10	0.829

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.4	62.9	N/A	62.0	N/A	61.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	11.5	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
40.4	36.1	32.3	30.8	64.0	4.6	2.1	27.6	65.5	24.9	66.8	22.3	68.0	19.0	69.5		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.3	45.8	45.0	45.0	46.1	49.3	52.8	56.5	59.0	57.4	53.3	48.1	45.6
	DBStd	5.93	4.69	4.17	4.28	2.81	2.66	2.35	2.14	2.10	1.83	2.49	3.55	3.35
	HDD50	849	146	151	170	122	44	4	0	0	0	3	71	138
	HDD65	5348	596	561	621	568	488	366	263	187	229	362	506	601
	CDD50	977	16	10	14	4	21	87	202	278	221	106	16	2
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	16.7	20.4	19.0	18.8	16.3	14.5	13.7	13.7	12.8	14.3	17.4	19.3	20.7
Precipitation	PrecAvg	116.7	13.8	9.8	10.6	8.3	5.5	4.7	4.0	5.3	8.1	14.8	16.7	15.2
	PrecMax	145.8	20.7	16.9	20.6	16.0	11.2	8.1	11.5	11.2	15.0	23.8	23.9	25.7
	PrecMin	93.9	6.7	4.3	4.0	3.4	1.8	1.7	0.9	1.3	1.3	6.7	9.7	6.3
	PrecStd	13.8	3.5	3.3	3.1	2.2	2.0	1.5	2.4	2.2	3.3	4.4	3.9	4.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.4	58.2	58.2	59.0	61.7	60.3	62.8	64.7	62.1	61.6	55.9	53.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	58.1	56.5	56.6	52.8	54.4	58.3	61.3	63.4	61.2	59.6	54.4	51.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	56.1	54.5	55.1	50.7	53.0	56.9	60.3	62.7	60.8	58.1	53.4	50.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	50.3	49.5	49.9	49.3	52.3	55.9	59.6	62.0	60.2	56.9	52.5	49.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	3.3	3.2	3.5	3.8	2.8	2.4	2.4	2.4	2.7	3.2	3.9	3.7
		MCDBR	2.6	2.3	1.9	6.5	3.6	3.1	2.8	2.8	3.1	3.6	3.9	3.7
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.327	0.332	0.361	0.393	0.393	0.375	0.370	0.378	0.375	0.354	0.333	0.318
	taud		2.398	2.467	2.386	2.288	2.342	2.451	2.515	2.492	2.462	2.440	2.376	2.364
	Ebn at Noon		220	255	266	268	274	280	279	271	259	241	213	202
	Edh at Noon		20	24	31	38	37	34	31	31	29	24	20	18
All-Sky Solar Radiation	RadAvg		229	501	838	1307	1586	1689	1609	1408	1051	592	293	191
	RadStd		27	72	93	76	121	153	159	130	86	64	34	25

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)	N/A	N/A	N/A	+0.76	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page