

EAST DELLWOOD BUOY 46207, Canada

WMO: 996620

Lat: 50.870N

Lon: 129.920W

Elev: 3

StdP: 101.29

Time Zone: -9.00 (W09)

Period: 01-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	1.0	2.6	N/A	N/A	N/A	N/A	N/A	N/A	20.1	7.2	18.7	7.0	8.3	10	0.829

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.3	17.1	N/A	16.7	N/A	16.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.1	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.1	16.2	14.4	DB	-0.6	17.8	2.5	1.2	-2.5	18.6	-4.0	19.3	-5.4	20.0	-7.2	20.8	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.2	7.7	7.2	7.2	7.8	9.6	11.6	13.6	15.0	14.1	11.8	9.0	7.6		
	DBStd	3.30	2.60	2.31	2.38	1.56	1.48	1.30	1.19	1.16	1.02	1.39	1.97	1.86		
	HDD10.0	472	81	84	94	68	24	2	0	0	0	2	39	77		
	HDD18.3	2971	331	312	345	316	271	203	146	104	127	201	281	334		
	CDD10.0	543	9	6	8	2	12	48	112	154	123	59	9	1		
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	7.5	9.1	8.5	8.4	7.3	6.5	6.1	6.1	5.7	6.4	7.8	8.6	9.2		
(15) Precipitation	PrecAvg	2965	351	250	268	212	139	120	101	135	205	375	423	387		
	PrecMax	3703	526	430	524	407	284	205	293	284	380	604	607	654		
	PrecMin	2385	170	109	102	87	46	43	22	33	32	169	247	159		
	PrecStd	351	89	83	80	56	51	38	60	57	85	112	99	104		
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.2	14.5	14.6	15.0	16.5	15.7	17.1	18.1	16.7	16.5	13.3	11.8		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	14.5	13.6	13.6	11.6	12.5	14.6	16.3	17.5	16.2	15.3	12.5	11.0		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	13.4	12.5	12.8	10.4	11.7	13.8	15.7	17.0	16.0	14.5	11.9	10.4		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	10.2	9.7	9.9	9.6	11.3	13.3	15.3	16.6	15.7	13.9	11.4	9.8		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% DB	MDBR	1.9	1.8	1.9	2.1	1.5	1.3	1.3	1.3	1.5	1.8	2.1	2.1		
		MCDBR	1.4	1.3	1.1	3.6	2.0	1.7	1.6	1.6	1.7	2.0	2.2	2.1		
(40) Clear-Sky Solar Irradiance	taub	taud	0.327	0.332	0.361	0.393	0.393	0.375	0.370	0.378	0.375	0.354	0.333	0.318		
		taud	2.398	2.467	2.386	2.288	2.342	2.451	2.515	2.492	2.462	2.440	2.376	2.364		
	Ebn at Noon	Ebn at Noon	693	803	838	846	863	882	881	855	816	760	672	637		
		Ebn at Noon	63	76	97	119	118	107	99	97	90	76	63	56		
	RadAvg	RadStd	0.72	1.58	2.64	4.12	5.00	5.33	5.07	4.44	3.31	1.86	0.92	0.60		
(45) All-Sky Solar Radiation			0.09	0.23	0.29	0.24	0.38	0.48	0.50	0.41	0.27	0.20	0.11	0.08		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47) Regional (12 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page