

K5 BUOY 64045, United KingdomWMO: **996770**Lat: **59.070N**Lon: **11.420W**Elev: **0**StdP: **14.70**Time Zone: **0.00 (EUW)**Period: **01-18**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	36.9	38.3	25.3	19.3	40.3	26.9	20.9	41.2	45.8	42.6	41.8	44.8	20.2	10	0.881

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.4	58.5	56.6	57.9	56.0	57.4	55.5	57.6	58.0	56.9	57.4	56.3	57.0	14.7	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
57.3	70.0	57.8	56.5	68.0	57.3	55.7	66.2	56.8	24.9	58.1	24.4	57.6	24.0	57.2	64.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 39.9	35.6	32.6	32.3	61.1	3.0	3.4	30.1	63.6	28.3	65.6	26.7	67.5	24.5	70.0		
(5)			29.8	59.5	3.0	2.0	27.7	60.9	26.0	62.1	24.3	63.2	22.1	64.6	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	49.2	45.6	45.1	45.2	47.0	48.4	51.9	54.1	55.0	54.0	50.6	47.9	45.8
	DBStd	4.52	2.98	3.29	3.09	2.86	2.82	2.52	2.00	1.53	2.04	2.97	2.99	3.26
	HDD50	827	139	139	148	94	63	11	0	0	1	29	71	132
	HDD65	5752	603	559	612	541	514	394	338	309	329	447	512	594
	CDD50	551	2	0	0	3	14	67	127	156	122	47	10	3
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	17.7	21.5	20.9	19.9	16.9	15.1	12.8	12.2	14.3	17.4	19.0	21.2	20.8
Precipitation	PrecAvg	51.3	6.1	5.2	4.7	2.8	2.1	2.6	3.5	3.1	4.6	5.1	5.4	6.0
	PrecMax	57.8	9.4	8.8	8.8	4.7	3.1	3.9	5.0	6.1	6.5	7.9	8.1	10.6
	PrecMin	39.5	1.3	2.6	1.7	1.0	0.9	1.3	1.9	1.8	3.0	1.8	2.3	3.3
	PrecStd	5.1	1.8	1.5	1.5	1.0	0.5	0.7	0.7	0.8	0.9	1.5	1.5	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.5	51.6	51.3	53.4	58.5	58.0	61.5	59.8	58.5	57.7	54.0	52.9
		MCWB	49.9	48.9	48.9	50.1	55.6	56.2	60.1	57.7	56.6	55.2	51.9	50.8
	2%	DB	51.7	51.0	50.7	52.0	54.3	57.2	58.5	58.3	57.9	56.6	53.2	52.0
		MCWB	49.5	48.5	48.4	49.5	51.9	55.3	57.0	56.4	56.1	54.4	50.9	49.9
	5%	DB	50.9	50.3	50.1	51.1	52.6	56.4	57.7	57.7	57.4	55.3	52.5	51.3
		MCWB	48.6	48.1	48.0	48.9	50.7	54.4	56.0	55.6	55.8	53.6	50.2	49.0
	10%	DB	49.9	49.7	49.5	50.5	51.9	55.4	56.9	57.3	56.8	54.6	51.9	50.6
		MCWB	47.5	47.4	47.2	48.4	50.1	53.3	54.8	55.2	55.2	52.6	49.7	48.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.1	50.4	50.2	51.1	55.5	57.2	60.5	58.4	57.5	56.2	53.0	51.9
		MCDB	51.8	50.8	50.5	51.9	58.2	57.5	61.8	59.2	58.0	56.9	53.2	52.3
	2%	WB	50.2	49.6	49.3	50.3	52.5	56.0	57.8	57.4	57.0	55.0	51.9	50.6
		MCDB	51.3	50.3	50.1	51.3	53.7	56.6	58.2	57.9	57.4	55.8	52.6	51.6
	5%	WB	49.2	48.8	48.6	49.6	51.3	54.9	56.7	56.7	56.5	54.3	51.1	49.7
		MCDB	50.7	50.0	49.7	50.8	52.1	55.8	57.3	57.3	57.1	55.2	52.1	51.1
	10%	WB	47.9	47.8	47.7	48.9	50.5	53.7	55.7	56.1	55.8	53.3	50.3	48.7
		MCDB	49.7	49.5	49.3	50.3	51.6	55.0	56.5	57.0	56.7	54.4	51.7	50.5
Mean Daily Temperature Range	5% DB	MDBR	4.7	4.6	4.3	3.2	2.9	2.2	2.4	2.4	2.7	3.5	4.0	5.0
		MCDBR	5.3	4.6	4.2	2.9	3.3	2.8	3.2	2.7	2.9	3.3	3.9	4.8
		MCWBR	6.7	6.0	5.4	3.8	3.5	3.2	3.6	3.5	4.2	4.3	5.5	6.4
	5% WB	MCDBR	5.1	4.7	3.9	2.9	2.9	2.7	3.1	2.7	3.0	3.4	4.1	5.0
		MCWBR	6.8	6.3	5.2	3.8	3.2	3.3	3.5	3.6	4.4	4.6	5.9	6.9
Clear-Sky Solar Irradiance	taub	0.343	0.365	0.372	0.393	0.385	0.378	0.380	0.374	0.381	0.354	0.331	0.311	
	taud	2.104	2.194	2.286	2.269	2.355	2.434	2.449	2.463	2.359	2.301	2.159	2.060	
	Ebn at Noon	133	198	240	256	268	272	268	261	236	201	137	101	
	Edh at Noon	16	25	30	36	35	33	32	29	28	22	15	12	
All-Sky Solar Radiation	RadAvg	89	264	618	1129	1551	1555	1398	1186	764	371	130	58	
	RadStd	7	25	56	87	101	127	125	86	52	28	12	5	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page