

K5 BUOY 64045, United KingdomWMO: **996770**Lat: **59.070N**Lon: **11.420W**Elev: **0**StdP: **101.33**Time Zone: **0.00 (EUW)**Period: **01-18**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	2.7	3.5	-3.7	2.8	4.6	-2.8	3.0	5.1	20.5	5.9	18.7	7.1	9.0	10	0.881

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.3	14.7	13.7	14.4	13.3	14.1	13.0	14.2	14.4	13.8	14.1	13.5	13.9	6.6	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.0	10.0	14.3	13.6	9.7	14.0	13.2	9.5	13.8	40.0	14.5	38.9	14.2	38.1	14.0	17.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.8	15.9	14.6	DB	0.1	16.2	1.7	1.9	-1.1	17.5	-2.0	18.6	-3.0	19.7	-4.2	21.1	(4)
(5)			WB	-1.2	15.3	1.6	1.1	-2.4	16.0	-3.4	16.7	-4.3	17.3	-5.5	18.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.6	7.5	7.3	7.4	8.3	9.1	11.0	12.3	12.8	12.2	10.3	8.9	7.7	(6)	
	DBStd	2.51	1.65	1.83	1.72	1.59	1.57	1.40	1.11	0.85	1.13	1.65	1.66	1.81	(7)	
	HDD10.0	459	77	77	82	52	35	6	0	0	1	16	39	73	(8)	
	HDD18.3	3196	335	311	340	301	286	219	188	172	183	248	284	330	(9)	
	CDD10.0	306	1	0	0	2	8	37	71	87	68	26	6	2	(10)	
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)	
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	7.9	9.6	9.4	8.9	7.6	6.7	5.7	5.5	6.4	7.8	8.5	9.5	9.3	(14)	
(15) Precipitation	PrecAvg	1302	155	131	120	70	54	65	90	80	117	130	136	153	(15)	
	PrecMax	1469	240	224	223	119	78	99	126	156	166	200	207	268	(16)	
	PrecMin	1003	34	67	44	25	22	32	47	45	75	45	59	83	(17)	
	PrecStd	129	45	38	37	25	13	18	19	21	23	39	37	43	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.4	10.9	10.7	11.9	14.7	14.4	16.4	15.4	14.7	14.3	12.2	11.6	(19)	
		MCWB	9.9	9.4	9.4	10.1	13.1	13.4	15.6	14.3	13.6	12.9	11.1	10.4	(20)	
	2%	DB	10.9	10.5	10.4	11.1	12.4	14.0	14.7	14.6	14.4	13.7	11.8	11.1	(21)	
		MCWB	9.7	9.2	9.1	9.7	11.0	13.0	13.9	13.5	13.4	12.5	10.5	9.9	(22)	
	5%	DB	10.5	10.2	10.1	10.6	11.5	13.5	14.3	14.3	14.1	13.0	11.4	10.7	(23)	
		MCWB	9.2	8.9	8.9	9.4	10.4	12.5	13.3	13.1	13.2	12.0	10.1	9.4	(24)	
	10%	DB	10.0	9.8	9.7	10.3	11.0	13.0	13.8	14.1	13.8	12.5	11.1	10.3	(25)	
		MCWB	8.6	8.6	8.4	9.1	10.1	11.9	12.7	12.9	12.9	11.5	9.8	9.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.6	10.2	10.1	10.6	13.1	14.0	15.8	14.7	14.2	13.4	11.6	11.1	(27)	
		MCDB	11.0	10.4	10.3	11.1	14.5	14.1	16.5	15.1	14.4	13.8	11.8	11.3	(28)	
	2%	WB	10.1	9.8	9.6	10.1	11.4	13.3	14.3	14.1	13.9	12.8	11.0	10.3	(29)	
		MCDB	10.7	10.2	10.0	10.7	12.1	13.7	14.6	14.4	14.1	13.2	11.4	10.9	(30)	
	5%	WB	9.6	9.3	9.2	9.8	10.7	12.7	13.7	13.7	13.6	12.4	10.6	9.8	(31)	
		MCDB	10.4	10.0	9.9	10.4	11.2	13.2	14.1	14.1	13.9	12.9	11.2	10.6	(32)	
	10%	WB	8.8	8.8	8.7	9.4	10.3	12.1	13.2	13.4	13.2	11.8	10.1	9.3	(33)	
		MCDB	9.9	9.7	9.6	10.2	10.9	12.8	13.6	13.9	13.7	12.4	10.9	10.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	2.6	2.6	2.4	1.8	1.6	1.2	1.3	1.3	1.5	1.9	2.2	2.8	(35)	
		MCDBR	2.9	2.5	2.3	1.6	1.8	1.5	1.8	1.5	1.6	1.8	2.2	2.7	(36)	
		MCWBR	3.7	3.3	3.0	2.1	2.0	1.8	2.0	1.9	2.3	2.4	3.0	3.5	(37)	
	5% WB	MCDBR	2.8	2.6	2.1	1.6	1.6	1.5	1.7	1.5	1.6	1.9	2.3	2.8	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.343	0.365	0.372	0.393	0.385	0.378	0.380	0.374	0.381	0.354	0.331	0.311	(40)	
		taud	2.104	2.194	2.286	2.269	2.355	2.434	2.449	2.463	2.359	2.301	2.159	2.060	(41)	
	Edh at Noon	Edh at Noon	419	624	757	807	845	858	846	824	743	634	433	317	(42)	
		Edh at Noon	52	78	94	112	111	104	100	92	87	69	48	38	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.28	0.83	1.95	3.56	4.89	4.90	4.41	3.74	2.41	1.17	0.41	0.18	(44)	
	RadStd	RadStd	0.02	0.08	0.17	0.27	0.32	0.40	0.39	0.27	0.16	0.09	0.04	0.01	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page