

NORTH SEA STATION 62132, United Kingdom

WMO: 996790

Lat: 56.400N

Lon: 2.000E

Elev: 0

StdP: 101.33

Time Zone: 0.00 (E00)

Period: 01-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	0.8	1.9	N/A	N/A	N/A	N/A	N/A	N/A	19.5	6.6	18.3	6.5	6.3	80	0.792

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.5	20.3	N/A	19.2	N/A	18.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.5	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.5	15.3	13.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.4	6.6	5.9	6.1	8.1	10.4	12.7	15.1	16.4	14.4	11.7	9.6	7.3		
	DBStd	4.00	1.66	1.81	2.02	1.89	2.21	1.79	1.89	2.01	1.76	1.86	1.59	2.11		
	HDD10.0	544	107	113	123	62	21	2	0	0	0	6	24	87		
	HDD18.3	2913	365	347	381	307	247	169	103	67	118	205	261	343		
	CDD10.0	681	0	0	1	6	32	82	157	197	132	59	13	1		
	CDD18.3	8	0	0	0	0	0	0	2	6	1	0	0	0		
	CDH23.3	1	0	0	0	0	0	0	1	1	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	7.1	9.1	8.2	7.5	6.2	6.2	5.6	5.2	6.0	6.4	7.8	8.5	8.5		
(15) Precipitation	PrecAvg	1132	134	110	98	55	46	64	73	85	97	111	129	131		
	PrecMax	1426	226	196	173	91	75	108	108	157	151	187	190	295		
	PrecMin	834	46	56	40	30	21	34	33	28	45	39	69	65		
	PrecStd	142	49	39	30	17	13	18	21	25	27	36	31	48		
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.0	10.9	10.9	14.3	18.6	18.3	21.3	22.4	20.5	19.0	14.3	12.0		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	9.7	9.2	9.2	12.5	15.4	16.4	19.4	20.7	18.2	15.7	13.1	11.1		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	9.1	8.5	8.7	11.1	13.9	15.5	18.3	19.7	17.2	14.9	12.4	10.4		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	8.6	8.0	8.2	10.2	12.9	14.8	17.5	18.8	16.5	14.2	11.8	9.8		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	2.3	2.6	2.5	3.1	3.1	2.3	2.5	2.5	2.6	2.5	2.4	2.7		
		MCDBR	2.7	3.5	3.1	4.9	5.5	3.5	3.9	4.0	3.9	3.5	3.3	3.4		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.334	0.350	0.370	0.397	0.381	0.386	0.392	0.389	0.377	0.353	0.335	0.313		
	taud		2.219	2.299	2.310	2.275	2.402	2.412	2.406	2.419	2.432	2.395	2.272	2.201		
	Ebn at Noon		536	699	784	818	859	857	843	820	775	690	533	457		
	Edh at Noon		57	77	96	115	108	108	107	99	85	69	53	45		
(44) All-Sky Solar Radiation	RadAvg		0.43	1.08	2.38	4.13	5.59	5.56	5.23	4.30	2.87	1.48	0.59	0.31		
	RadStd		0.05	0.15	0.21	0.30	0.37	0.34	0.52	0.28	0.33	0.10	0.06	0.04		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page