

K7 BUOY 64046, United Kingdom

WMO: 996840

Lat: 60.483N

Lon: 4.167W

Elev: 0

StdP: 14.70

Time Zone: 0.00 (EUW)

Period: 02-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	34.2	35.8	21.2	15.9	40.6	23.9	18.1	38.2	44.2	42.7	41.1	44.4	22.4	350	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.3	58.6	56.8	57.8	56.2	57.0	55.6	57.5	58.2	56.7	57.4	55.9	56.6	14.2	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.1	69.4	57.9	56.2	67.3	57.1	55.5	65.5	56.4	24.8	58.3	24.3	57.6	23.8	56.8	64.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 40.6	36.6	33.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.5	44.3	44.2	44.3	46.4	47.6	51.1	53.8	54.5	53.0	49.8	47.5	44.8
	DBStd	4.82	3.29	3.64	3.80	3.15	2.62	2.25	2.07	1.97	2.44	3.03	3.64	3.93
	HDD50	1014	177	162	178	110	79	13	0	0	6	40	86	163
	HDD65	6030	641	582	642	557	538	418	346	325	359	471	526	625
	CDD50	458	0	0	1	3	6	45	119	140	97	34	10	3
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
	WSAvg	18.1	22.3	21.4	20.9	17.9	15.4	13.2	13.2	13.8	15.5	20.1	21.3	22.8
	PrecAvg	49.5	5.9	4.8	4.4	2.7	1.9	2.6	3.3	3.7	4.6	5.0	5.0	5.7
(15) Precipitation	PrecMax	60.4	8.3	9.1	8.7	4.6	3.7	4.1	4.6	5.6	7.0	7.7	7.9	9.5
	PrecMin	34.1	1.7	1.7	1.7	1.2	0.9	1.2	1.8	2.4	2.4	1.9	2.0	2.7
	PrecStd	5.7	1.7	1.9	1.6	0.9	0.6	0.8	0.6	0.8	1.2	1.5	1.3	1.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.3	52.0	52.9	53.0	53.9	57.4	59.7	60.0	59.3	55.8	54.8	52.9
		MCWB	50.3	50.0	50.1	50.5	51.9	55.5	58.0	58.0	57.3	53.5	52.6	50.5
	2%	DB	50.7	50.7	51.4	52.0	52.2	56.2	58.4	58.7	57.8	55.0	53.4	51.7
		MCWB	48.5	48.9	48.9	49.8	50.3	54.3	57.0	56.9	56.0	52.9	51.1	49.6
	5%	DB	49.5	49.6	50.1	51.2	51.5	54.9	57.6	57.9	56.6	54.4	52.6	50.9
		MCWB	47.1	47.9	47.4	49.1	49.6	53.1	56.4	56.2	55.0	52.3	50.4	48.5
	10%	DB	48.5	48.9	49.2	50.2	50.9	54.0	56.7	57.2	55.9	53.7	51.8	50.0
		MCWB	45.9	47.3	46.5	48.3	49.0	52.3	55.6	55.6	54.5	51.6	49.7	47.6
	0.4%	WB	51.0	51.3	50.7	51.2	52.5	56.1	58.5	58.4	57.6	54.9	53.2	51.4
		MCDB	51.6	51.5	52.4	52.4	53.3	57.1	59.1	58.9	58.6	55.2	54.5	52.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	49.2	49.5	49.4	50.3	51.1	54.7	57.6	57.4	56.5	53.9	51.9	50.3
		MCDB	50.3	50.0	51.0	51.5	51.9	55.8	58.2	58.0	57.4	54.8	52.9	51.4
	5%	WB	47.7	48.7	48.2	49.5	50.2	53.6	56.8	56.6	55.6	53.1	51.0	49.3
		MCDB	49.1	49.3	49.6	50.7	51.2	54.6	57.5	57.4	56.3	54.2	52.3	50.8
	10%	WB	46.6	47.8	47.1	48.6	49.4	52.7	55.9	55.9	55.0	52.2	50.3	48.1
		MCDB	48.4	48.7	48.9	49.9	50.6	53.8	56.5	56.7	55.7	53.4	51.8	50.0
	5% DB	MDBR	4.6	4.1	4.3	3.5	2.9	2.4	2.4	2.3	2.7	3.5	4.0	5.1
		MCDBR	5.6	4.3	5.0	3.8	2.6	3.2	3.3	2.8	3.1	3.4	3.7	5.7
		MCWBR	6.9	5.2	5.7	4.3	3.0	3.0	3.4	3.0	3.4	4.1	4.3	6.8
		MCWBR	5.3	4.1	5.0	3.8	2.9	2.9	3.4	2.5	2.7	3.5	3.6	5.4
(35) Mean Daily Temperature Range	5% WB	MCWBR	6.7	5.4	6.1	4.4	3.4	3.0	3.5	3.0	3.2	4.5	4.5	7.0
(40) Clear-Sky Solar Irradiance	taub		0.338	0.358	0.369	0.390	0.376	0.369	0.380	0.368	0.367	0.350	0.326	0.410
	taud		2.077	2.192	2.276	2.276	2.387	2.451	2.439	2.474	2.422	2.302	2.134	2.388
	Ebn at Noon		117	192	236	255	269	273	267	261	238	195	121	78
	Edh at Noon		15	23	29	35	34	32	32	29	25	21	14	10
(44) All-Sky Solar Radiation	RadAvg		71	233	592	1089	1513	1576	1415	1190	715	352	108	44
	RadStd		7	22	45	88	130	149	118	97	60	31	12	3

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (14 neighbors)	+0.58	N/A	+1.48	N/A	N/A	N/A	N/A	-160	-205	N/A	N/A

Nomenclature: See separate page