

K7 BUOY 64046, United Kingdom

WMO: 996840

Lat: 60.483N

Lon: 4.167W

Elev: 0

StdP: 101.33

Time Zone: 0.00 (EUW)

Period: 02-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	1.2	2.1	-6.0	2.3	4.8	-4.5	2.6	3.4	19.7	6.0	18.4	6.9	10.0	350	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.3	14.8	13.8	14.3	13.5	13.9	13.1	14.2	14.5	13.7	14.1	13.3	13.7	6.3	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.9	9.9	14.4	13.5	9.6	14.0	13.0	9.4	13.5	39.8	14.6	38.6	14.2	37.5	13.8	18.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.2	16.4	14.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.2	6.8	6.8	6.8	8.0	8.7	10.6	12.1	12.5	11.7	9.9	8.6	7.1
	DBStd	2.68	1.83	2.02	2.11	1.75	1.46	1.25	1.15	1.10	1.36	1.68	2.02	2.18
	HDD10.0	563	98	90	99	61	44	7	0	0	3	22	48	91
	HDD18.3	3350	356	323	357	309	299	232	192	181	199	262	292	347
	CDD10.0	254	0	0	1	2	3	25	66	78	54	19	6	2
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	8.1	10.0	9.6	9.3	8.0	6.9	5.9	5.9	6.2	6.9	9.0	9.5	10.2
Precipitation	PrecAvg	1258	151	123	113	69	49	65	83	93	116	126	126	144
	PrecMax	1534	212	232	221	116	95	103	118	143	179	196	201	242
	PrecMin	865	42	42	44	31	23	30	46	61	60	49	50	68
	PrecStd	146	44	47	40	23	16	20	15	21	30	38	33	38
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.3	11.1	11.6	11.7	12.2	14.1	15.4	15.6	15.2	13.2	12.7	11.6
		MCWB	10.1	10.0	10.0	10.3	11.1	13.1	14.4	14.4	14.0	11.9	11.4	10.3
	2%	DB	10.4	10.4	10.8	11.1	11.2	13.5	14.7	14.8	14.4	12.8	11.9	10.9
		MCWB	9.2	9.4	9.4	9.9	10.2	12.4	13.9	13.8	13.3	11.6	10.6	9.8
	5%	DB	9.7	9.8	10.1	10.7	10.9	12.7	14.2	14.4	13.7	12.4	11.4	10.5
		MCWB	8.4	8.9	8.6	9.5	9.8	11.7	13.5	13.5	12.8	11.3	10.2	9.2
	10%	DB	9.2	9.4	9.5	10.1	10.5	12.2	13.7	14.0	13.3	12.1	11.0	10.0
		MCWB	7.7	8.5	8.1	9.1	9.4	11.3	13.1	13.1	12.5	10.9	9.8	8.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.6	10.7	10.4	10.7	11.4	13.4	14.7	14.7	14.2	12.7	11.8	10.8
		MCDB	10.9	10.8	11.3	11.3	11.8	13.9	15.1	15.0	14.8	12.9	12.5	11.1
	2%	WB	9.6	9.7	9.7	10.1	10.6	12.6	14.2	14.1	13.6	12.2	11.0	10.2
		MCDB	10.1	10.0	10.5	10.8	11.0	13.2	14.5	14.5	14.1	12.7	11.6	10.8
	5%	WB	8.7	9.3	9.0	9.7	10.1	12.0	13.8	13.7	13.1	11.7	10.6	9.6
		MCDB	9.5	9.6	9.8	10.4	10.7	12.5	14.1	14.1	13.5	12.3	11.3	10.4
	10%	WB	8.1	8.8	8.4	9.2	9.7	11.5	13.3	13.3	12.8	11.2	10.1	8.9
		MCDB	9.1	9.3	9.4	9.9	10.3	12.1	13.6	13.7	13.2	11.9	11.0	10.0
Mean Daily Temperature Range	5% DB	MDBR	2.6	2.3	2.4	2.0	1.6	1.4	1.3	1.3	1.5	1.9	2.2	2.8
		MCDBR	3.1	2.4	2.8	2.1	1.5	1.8	1.8	1.5	1.7	1.9	2.1	3.2
		MCWBR	3.8	2.9	3.2	2.4	1.7	1.7	1.9	1.7	1.9	2.3	2.4	3.8
	5% WB	MCDBR	3.0	2.3	2.8	2.1	1.6	1.6	1.9	1.4	1.5	1.9	2.0	3.0
		MCWBR	3.7	3.0	3.4	2.4	1.9	1.7	1.9	1.7	1.8	2.5	2.5	3.9
Clear-Sky Solar Irradiance	taub	0.338	0.358	0.369	0.390	0.376	0.369	0.380	0.368	0.367	0.350	0.326	0.410	
	taud	2.077	2.192	2.276	2.276	2.387	2.451	2.439	2.474	2.422	2.302	2.134	2.388	
	Ebn at Noon	369	606	745	803	849	862	841	823	750	614	382	246	
	Edh at Noon	47	74	92	110	106	101	100	90	80	65	43	32	
All-Sky Solar Radiation	RadAvg	0.22	0.73	1.87	3.43	4.77	4.97	4.46	3.75	2.25	1.11	0.34	0.14	
	RadStd	0.02	0.07	0.14	0.28	0.41	0.47	0.37	0.31	0.19	0.10	0.04	0.01	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (14 neighbors)		+0.32	N/A	+0.82	N/A	N/A	N/A	-89	-114	N/A	N/A	

Nomenclature: See separate page