

TURBOT BANK BUOY 62303, United Kingdom

WMO: 996860

Lat: 51.600N

Lon: 5.100W

Elev: 0

StdP: 14.70

Time Zone: 0.00 (EUW)

Period: 01-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	35.4	37.5	25.1	19.1	38.9	27.7	21.6	39.9	36.7	47.6	34.6	46.8	15.0	60	0.764

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.1	64.7	61.7	63.7	61.1	62.9	60.5	62.8	63.8	61.9	63.0	61.1	62.4	13.5	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.2	83.7	63.3	61.2	80.9	62.6	60.4	78.4	62.1	28.3	63.9	27.7	63.2	27.2	62.6	68.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
34.5	31.5	28.8	DB	33.3	67.1	2.1	3.1	31.8	69.4	30.5	71.2	29.3	73.0	27.8	75.2
			WB	30.7	63.9	2.2	2.3	29.2	65.6	27.9	66.9	26.6	68.2	25.0	69.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	52.6	46.6	45.4	46.4	48.9	52.0	56.1	59.4	60.6	59.3	56.0	52.1	47.9	(6)
(7)		DBStd	6.11	4.19	3.63	2.66	2.36	2.24	1.96	1.90	1.69	2.05	3.15	3.69	4.48	(7)
(8)		HDD50	525	113	132	113	47	6	0	0	0	0	3	21	90	(8)
(9)		HDD65	4533	571	550	577	484	404	268	175	136	171	280	387	530	(9)
(10)		CDD50	1467	7	2	1	13	68	182	290	329	279	188	84	24	(10)
(11)		CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	15.4	17.9	15.6	14.8	12.6	13.7	12.0	12.7	13.5	15.4	17.9	19.1	19.3	(14)
(15)	Precipitation	PrecAvg	41.6	4.4	3.2	2.7	2.6	2.6	2.8	3.5	3.0	4.6	5.2	4.3	(15)	
(16)		PrecMax	50.9	7.1	7.5	5.5	5.7	5.3	5.7	7.6	8.0	5.4	7.6	10.2	7.7	(16)
(17)		PrecMin	35.1	0.4	0.7	0.9	0.9	0.3	0.4	0.6	1.0	0.4	1.3	2.9	1.1	(17)
(18)		PrecStd	4.8	1.8	1.6	1.3	1.3	1.3	1.4	1.5	1.8	1.3	1.7	2.0	1.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.9	52.6	52.8	56.9	60.6	62.3	66.2	66.6	66.1	62.6	58.6	56.5	(19)
(20)			MCWB	52.0	50.5	48.3	50.9	55.3	58.3	61.6	63.1	61.9	60.7	54.9	54.5	(20)
(21)		2%	DB	53.0	51.4	51.2	54.3	57.5	60.4	64.0	64.9	63.5	61.4	57.9	54.9	(21)
(22)			MCWB	51.0	49.6	48.2	50.6	53.9	57.8	61.0	62.0	60.9	59.3	54.5	52.7	(22)
(23)		5%	DB	52.2	50.5	50.3	53.0	55.8	59.4	62.9	64.1	62.7	60.7	57.3	54.0	(23)
(24)			MCWB	50.1	48.8	47.8	50.1	53.2	57.1	60.6	61.5	60.3	58.6	54.1	51.6	(24)
(25)		10%	DB	51.5	49.8	49.6	52.0	54.8	58.6	62.0	63.3	62.0	60.0	56.6	53.4	(25)
(26)			MCWB	49.3	48.0	47.4	49.4	52.5	56.5	59.9	60.8	59.6	57.8	53.5	50.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.9	51.1	50.2	53.2	55.8	59.7	62.9	64.1	63.2	61.5	57.4	55.4	(27)
(28)			MCDWB	53.3	51.9	50.7	54.3	57.9	61.1	63.8	65.3	64.7	61.9	58.1	56.3	(28)
(29)		2%	WB	51.8	50.1	49.3	51.8	54.7	58.5	61.9	63.2	62.0	60.3	56.2	53.7	(29)
(30)			MCDWB	52.6	51.0	50.1	53.3	56.4	59.7	63.1	64.3	63.0	61.0	57.5	54.7	(30)
(31)		5%	WB	50.8	49.3	48.6	50.7	53.9	57.8	61.1	62.3	61.1	59.3	55.3	52.4	(31)
(32)			MCDWB	51.9	50.3	49.7	52.2	55.4	59.0	62.5	63.4	62.2	60.3	56.9	53.7	(32)
(33)		10%	WB	49.9	48.4	48.1	50.0	53.0	57.2	60.3	61.5	60.3	58.4	54.3	51.4	(33)
(34)			MCDWB	51.2	49.6	49.4	51.3	54.5	58.3	61.8	62.8	61.6	59.7	56.2	53.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.2	3.9	3.7	3.8	3.4	3.3	3.0	3.1	3.5	3.9	3.9	4.6	(35)
(36)			MCDBR	4.3	4.2	3.8	5.6	5.0	4.5	4.2	3.9	3.9	3.5	3.7	5.2	(36)
(37)			MCWBR	5.4	4.4	4.0	4.7	4.4	4.3	3.8	3.8	4.2	4.6	5.1	6.7	(37)
(38)		5% WB	MCDWB	4.2	3.9	3.3	4.1	4.3	4.0	3.8	3.4	3.3	3.5	3.5	4.9	(38)
(39)			MCWBR	5.5	4.4	4.0	4.0	4.1	4.3	3.9	3.9	4.3	4.9	5.3	6.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.338	0.349	0.377	0.388	0.398	0.383	0.389	0.372	0.367	0.359	0.336	0.328	(40)	
(41)		taud	2.329	2.377	2.327	2.332	2.353	2.426	2.414	2.477	2.476	2.444	2.384	2.306	(41)	
(42)		Ebn at Noon	208	243	258	269	272	277	273	272	260	237	208	189	(42)	
(43)		Edh at Noon	21	26	32	36	37	35	35	31	28	24	19	18	(43)	
(44)	All-Sky Solar Radiation	RadAvg	236	484	877	1403	1719	1870	1708	1425	1056	585	295	179	(44)	
(45)		RadStd	23	43	78	99	108	157	140	95	79	47	23	23	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (42 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page