

HALIBUT BANK BUOY 46146, BC, Canada

WMO: 996870

Lat: 49.340N

Lon: 123.730W

Elev: 10

StdP: 14.69

Time Zone: -8.00 (NAP)

Period: 02-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 31.4	(c) 33.9	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 33.5	(k) 42.7	(l) 30.9	(m) 43.6	(n) 10.5	(o) 110	(p) 0.627

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 5.5	(c) 71.7	(d) N/A	(e) 69.8	(f) N/A	(g) 68.2	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 8.6	(p) 280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 28.5	(b) 25.5	(c) 22.8	(e) 28.5	(f) 75.4	(g) 3.8	(h) 2.8	(i) 25.8	(j) 77.5	(k) 23.6	(l) 79.1	(m) 21.5	(n) 80.7	(o) 18.7	(p) 82.7		
			DB			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.8	42.4	42.9	45.0	49.1	54.8	59.5	63.9	64.3	58.5	52.4	46.1	42.6
	DBStd	8.72	4.06	3.38	3.37	3.18	3.88	4.08	3.19	2.78	3.39	3.06	4.24	4.13
	HDD50	1024	237	200	158	52	5	0	0	0	3	13	125	231
	HDD65	4858	701	620	621	477	316	172	58	48	194	389	567	695
	CDD50	1694	0	0	2	24	154	285	430	442	259	89	8	1
	CDD65	55	0	0	0	0	0	7	23	25	0	0	0	0
	CDH74	24	0	0	0	0	0	0	23	1	0	0	0	0
	CDH80	1	0	0	0	0	0	0	1	0	0	0	0	0
Wind	WSAvg	11.3	12.3	11.0	12.2	11.2	10.0	10.4	10.3	10.0	10.7	11.4	13.0	13.0
Precipitation	PrecAvg	61.6	8.7	5.9	5.6	3.9	3.0	2.5	1.7	2.0	2.7	6.8	9.3	9.0
	PrecMax	72.8	15.0	10.8	9.6	7.4	4.6	4.6	3.1	7.9	6.5	11.6	16.0	11.5
	PrecMin	49.8	5.7	1.9	2.2	1.6	1.0	0.9	0.4	0.4	0.8	2.3	4.9	6.3
	PrecStd	6.4	2.4	1.9	1.5	1.5	0.9	1.0	0.7	1.8	1.5	2.3	2.9	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.2	50.4	53.1	60.1	67.2	72.5	77.0	73.3	67.2	60.7	54.9	52.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	49.7	49.0	51.2	56.7	64.1	69.5	72.4	71.1	65.1	58.7	53.3	50.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	48.5	47.7	50.0	54.7	61.8	67.2	70.0	69.6	63.8	57.4	52.1	49.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	47.4	46.8	49.0	53.1	59.9	64.9	68.2	68.3	62.7	56.3	51.0	47.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	3.8	3.9	4.4	5.0	5.6	5.7	6.3	5.5	4.6	3.8	4.0	3.7
		MCDBR	4.8	4.3	5.1	6.6	7.7	8.1	8.0	6.7	5.6	5.0	4.8	4.7
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.317	0.308	0.331	0.362	0.378	0.368	0.356	0.356	0.339	0.333	0.315	0.304
	taud		2.461	2.533	2.484	2.416	2.400	2.443	2.517	2.519	2.568	2.554	2.533	2.480
	Ebn at Noon		235	271	281	281	280	283	285	280	275	257	235	224
	Edh at Noon		20	23	29	34	36	35	32	30	26	23	18	17
All-Sky Solar Radiation	RadAvg		267	542	805	1258	1649	1767	1971	1676	1163	636	315	212
	RadStd		44	84	113	135	151	213	182	137	105	93	60	33

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47) Regional (63 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page