

HALIBUT BANK BUOY 46146, BC, Canada

WMO: 996870

Lat: 49.340N

Lon: 123.730W

Elev: 3

StdP: 101.29

Time Zone: -8.00 (NAP)

Period: 02-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -0.3	(c) 1.1	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 15.0	(k) 6.0	(l) 13.8	(m) 6.4	(n) 4.7	(o) 110	(p) 0.627

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 3.0	(c) 22.0	(d) N/A	(e) 21.0	(f) N/A	(g) 20.1	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 3.8	(p) 280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 12.8	(b) 11.4	(c) 10.2	(e) -2.0	(f) 24.1	(g) 2.1	(h) 1.6	(i) -3.5	(j) 25.3	(k) -4.7	(l) 26.2	(m) -5.9	(n) 27.1	(o) -7.4	(p) 28.2		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.0	5.8	6.0	7.2	9.5	12.7	15.3	17.7	17.9	14.7	11.4	7.8	5.9		
	DBStd	4.84	2.25	1.88	1.87	1.77	2.16	2.27	1.77	1.54	1.88	1.70	2.35	2.30		
	HDD10.0	569	132	111	88	29	3	0	0	0	2	7	69	128		
	HDD18.3	2699	389	344	345	265	176	96	32	27	108	216	315	386		
	CDD10.0	941	0	0	1	13	86	158	239	246	144	49	4	1		
	CDD18.3	31	0	0	0	0	0	4	13	14	0	0	0	0		
	CDH23.3	13	0	0	0	0	0	0	13	1	0	0	0	0		
	CDH26.7	1	0	0	0	0	0	0	1	0	0	0	0	0		
(14) Wind	WSAvg	5.0	5.5	4.9	5.5	5.0	4.5	4.6	4.6	4.5	4.8	5.1	5.8	5.8		
(15) Precipitation	PrecAvg	1564	221	151	142	99	75	64	43	50	69	172	236	229		
	PrecMax	1849	382	275	245	188	116	118	78	201	165	295	407	292		
	PrecMin	1264	146	49	55	41	25	24	11	9	20	59	125	160		
	PrecStd	162	61	49	38	38	24	25	17	45	37	59	74	37		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.7	10.2	11.7	15.6	19.6	22.5	25.0	22.9	19.5	15.9	12.7	11.2		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	9.8	9.4	10.7	13.7	17.8	20.9	22.4	21.7	18.4	14.8	11.8	10.3		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	9.1	8.7	10.0	12.6	16.5	19.5	21.1	20.9	17.7	14.1	11.2	9.5		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	8.5	8.2	9.4	11.7	15.5	18.3	20.1	20.1	17.1	13.5	10.6	8.7		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	MDBR		2.1	2.2	2.5	2.8	3.1	3.2	3.5	3.0	2.6	2.1	2.2	2.1		
	5% DB	MCDBR	2.7	2.4	2.9	3.7	4.3	4.5	4.5	3.7	3.1	2.8	2.7	2.6		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.317	0.308	0.331	0.362	0.378	0.368	0.356	0.356	0.339	0.333	0.315	0.304		
	taud		2.461	2.533	2.484	2.416	2.400	2.443	2.517	2.519	2.568	2.554	2.533	2.480		
	Ebn at Noon		740	853	885	886	882	892	898	883	868	809	742	705		
	Edh at Noon		62	73	90	106	113	109	100	95	82	71	58	54		
(44) All-Sky Solar Radiation	RadAvg		0.84	1.71	2.54	3.97	5.20	5.57	6.21	5.28	3.67	2.00	0.99	0.67		
	RadStd		0.14	0.27	0.35	0.43	0.48	0.67	0.57	0.43	0.33	0.29	0.19	0.10		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (63 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page