

CORMORANT STATION 63112, United KingdomWMO: **996920**Lat: **61.100N**Lon: **1.000E**Elev: **98**StdP: **14.64**Time Zone: **0.00 (EUW)**Period: **01-18**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	32.1	34.1	18.9	14.3	35.9	21.2	15.9	37.1	49.6	40.0	46.9	39.0	21.3	350	0.877

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.2	66.4	60.9	64.1	59.5	62.2	57.9	62.2	65.3	60.3	63.3	58.7	61.5	12.4	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
60.7	79.5	64.1	58.7	74.1	62.2	57.2	70.0	60.4	28.0	65.4	26.6	63.6	25.6	61.7	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 43.6	38.9	34.2	29.6	72.5	2.5	4.9	27.8	76.0	26.4	78.8	24.9	81.6	23.1	85.1		
(5)			27.8	64.5	2.0	4.2	26.4	67.5	25.2	70.0	24.1	72.3	22.6	75.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.1	42.9	42.4	43.4	45.8	49.0	53.2	57.0	58.2	55.0	50.1	47.2	43.8		
	DBStd	6.63	3.62	4.08	4.19	3.68	3.68	3.76	3.57	3.13	3.33	3.62	3.83	4.64		
	HDD50	1172	220	212	205	130	61	9	0	0	4	42	93	196		
	HDD65	5827	685	632	670	576	496	353	250	213	300	461	533	658		
	CDD50	826	0	0	1	4	30	106	217	254	155	46	10	3		
	CDD65	4	0	0	0	0	0	1	2	1	0	0	0	0		
	CDH74	2	0	0	0	0	0	0	1	1	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	17.9	22.2	21.3	19.4	16.7	15.1	13.7	14.1	14.4	16.7	18.9	20.9	21.7		
(15) Precipitation	PrecAvg	52.8	6.3	5.2	5.0	2.8	1.9	2.6	3.2	3.9	4.6	5.6	5.5	6.1		
	PrecMax	65.0	9.9	10.1	9.3	4.8	3.3	5.2	6.0	6.4	7.5	8.5	8.7	9.4		
	PrecMin	37.6	3.0	2.3	1.8	1.0	0.9	1.0	1.6	2.6	1.9	2.3	1.7	2.6		
	PrecStd	6.5	1.9	2.1	1.8	0.9	0.6	0.9	0.9	1.0	1.3	1.6	1.5	1.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.9	53.1	53.4	55.7	61.5	68.0	70.6	70.1	64.9	59.4	56.5	54.6		
		MCWB	49.4	48.1	48.4	49.7	54.2	59.0	63.4	64.0	60.3	55.0	51.5	50.6		
	2%	DB	51.1	51.4	51.8	53.3	57.8	63.2	66.5	66.2	62.0	57.2	54.2	53.0		
		MCWB	47.4	47.4	47.6	48.3	51.6	56.8	60.9	61.8	57.6	52.8	50.1	49.5		
	5%	DB	49.3	49.2	50.2	51.7	55.6	60.5	64.0	64.0	60.4	55.7	52.8	51.1		
		MCWB	46.0	45.5	46.2	47.1	50.0	55.3	59.7	59.7	56.5	51.9	49.3	47.8		
	10%	DB	47.9	47.6	48.5	50.1	53.6	58.0	61.7	62.2	59.2	54.5	51.7	49.5		
		MCWB	44.9	44.3	45.0	46.3	49.0	53.9	58.1	58.3	55.7	51.0	48.4	46.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.4	49.5	49.4	51.1	54.9	59.9	64.0	64.9	61.0	56.3	52.8	51.5		
		MCDB	52.2	51.7	52.3	54.4	60.2	66.6	68.7	67.6	64.7	58.6	54.9	53.5		
	2%	WB	48.2	48.0	48.0	49.0	52.5	57.7	61.9	62.9	58.6	54.2	51.3	50.1		
		MCDB	49.9	50.4	51.0	52.0	56.3	62.1	65.4	65.4	60.9	56.1	53.3	52.3		
	5%	WB	46.7	46.3	46.7	47.8	51.1	55.7	60.3	60.7	57.4	52.9	50.2	48.6		
		MCDB	48.8	48.5	49.4	50.4	54.2	59.5	63.4	63.1	59.5	54.8	52.2	50.7		
	10%	WB	45.3	44.9	45.5	47.0	50.0	54.4	58.7	58.8	56.3	51.5	49.0	47.1		
		MCDB	47.7	47.4	48.1	49.6	52.7	57.5	61.6	61.3	58.6	53.6	51.3	49.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.9	5.8	6.4	6.6	7.1	6.7	6.5	6.2	5.6	5.4	5.7	6.2		
		MCDBR	7.9	7.9	7.7	8.7	9.9	10.7	10.0	9.2	7.3	7.1	6.9	7.8		
	5% WB	MCWBR	7.6	6.9	6.5	6.0	6.4	6.5	5.8	5.9	5.0	5.6	6.2	7.4		
		MCWBR	7.8	7.3	7.3	8.0	9.0	9.4	9.2	8.8	6.8	6.5	6.7	7.6		
(40) Clear-Sky Solar Irradiance	taub		0.335	0.355	0.368	0.380	0.370	0.363	0.380	0.369	0.365	0.346	0.321	0.385		
		taud	2.062	2.185	2.266	2.308	2.406	2.467	2.435	2.466	2.428	2.306	2.124	2.301		
	Ebn at Noon		109	189	234	257	271	275	266	260	237	193	114	69		
		Edh at Noon	14	23	29	34	33	31	32	29	25	20	13	9		
(44) All-Sky Solar Radiation	RadAvg		61	216	573	1114	1553	1583	1437	1152	699	329	95	38		
	RadStd		8	26	60	87	111	170	131	108	55	40	12	2		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (22 neighbors)	N/A	+1.17	+1.12	N/A	N/A	N/A	-184	-241	N/A	N/A

Nomenclature: See separate page