

SENTRY SHOAL BUOY 46131, BC, Canada

WMO: 996930

Lat: 49.910N

Lon: 124.990W

Elev: 3

StdP: 101.29

Time Zone: -8.00 (NAP)

Period: 01-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.7	0.8	N/A	N/A	N/A	N/A	N/A	N/A	16.2	7.0	15.1	7.2	5.6	320	0.622

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.0	23.0	N/A	21.7	N/A	20.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	2.7	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
14.2	12.6	11.2	-2.3	26.9	2.2	1.5	-3.9	28.0	-5.1	28.9	-6.3	29.7	-7.9	30.9		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.8	5.5	5.6	7.1	9.2	12.9	15.7	17.7	17.4	14.6	10.9	7.3	5.5
	DBStd	4.94	2.46	1.97	1.68	1.91	2.19	2.20	1.84	1.62	1.66	1.71	2.33	2.34
	HDD10.0	624	141	122	92	36	3	0	0	0	0	9	82	139
	HDD18.3	2776	399	356	349	273	169	86	34	39	113	230	330	397
	CDD10.0	921	0	0	1	13	93	170	238	229	137	38	2	1
	CDD18.3	32	0	0	0	0	1	6	14	10	1	0	0	0
	CDH23.3	33	0	0	0	0	1	9	19	4	0	0	0	0
	CDH26.7	2	0	0	0	0	0	1	1	1	0	0	0	0
Wind	WSAvg	4.9	5.2	4.6	5.6	5.0	4.4	4.5	4.6	4.1	4.2	4.8	5.5	5.8
Precipitation	PrecAvg	1238	181	116	116	71	50	48	29	38	54	140	192	204
	PrecMax	1678	362	331	235	162	119	106	53	135	181	340	373	339
	PrecMin	832	70	5	26	23	11	13	2	4	2	11	67	84
	PrecStd	208	69	71	51	40	26	25	14	28	42	78	91	64
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.7	10.3	11.4	16.7	20.6	24.6	25.5	23.7	20.6	15.9	12.4	11.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	9.9	9.4	10.6	14.8	18.5	22.1	23.3	22.4	18.9	14.8	11.5	10.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	9.2	8.7	9.8	13.1	17.1	20.2	21.8	21.2	17.9	13.9	10.9	9.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	8.6	8.1	9.2	11.8	15.9	18.7	20.6	20.1	17.0	13.1	10.2	8.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	2.3	2.6	2.9	3.7	4.2	4.5	5.0	4.5	3.6	2.6	2.4	2.3
		MCDBR	2.7	2.7	3.2	5.7	6.5	7.3	7.1	6.3	4.9	3.6	2.7	2.9
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.326	0.322	0.347	0.373	0.395	0.384	0.386	0.391	0.353	0.358	0.330	0.322
	taud		2.405	2.506	2.446	2.372	2.329	2.396	2.423	2.415	2.521	2.433	2.440	2.369
	Ebn at Noon		712	828	862	872	864	875	867	845	847	764	702	653
	Edh at Noon		65	74	93	111	120	114	109	105	85	79	62	58
All-Sky Solar Radiation	RadAvg		0.79	1.66	2.47	3.86	5.07	5.45	6.00	5.17	3.59	1.92	0.93	0.62
	RadStd		0.12	0.28	0.35	0.41	0.56	0.62	0.66	0.43	0.32	0.33	0.18	0.10

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (43 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page