

SOUTH BROOKS BUOY 46132, CanadaWMO: **996960**Lat: **49.740N**Lon: **127.930W**Elev: **10**StdP: **14.69**Time Zone: **-9.00 (W09)**Period: **02-18**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	35.2	37.7	N/A	N/A	N/A	N/A	N/A	N/A	44.2	44.1	40.7	44.5	17.3	340	0.836

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.8	62.7	N/A	61.6	N/A	60.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	12.2	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 39.6	35.5	31.8	DB	30.7	64.0	3.5	2.9	28.2	66.1	26.1	67.8	24.1	69.5	21.5	71.6	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.3	45.5	45.1	44.8	46.5	49.6	53.3	56.1	57.7	57.0	53.4	48.6	45.9
	DBStd	5.51	3.33	3.24	2.97	2.32	2.56	2.36	2.26	2.32	2.16	2.75	3.55	3.26
	HDD50	785	139	138	163	106	39	3	0	0	0	4	62	131
	HDD65	5356	603	557	627	554	478	352	276	225	240	359	492	593
	CDD50	905	1	1	1	2	26	101	189	240	210	111	20	3
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	16.7	18.6	17.1	17.6	16.1	15.4	15.1	15.8	15.2	15.1	16.6	17.8	19.5
Precipitation	PrecAvg	54.9	7.5	5.3	4.7	3.7	2.5	2.2	1.6	2.2	3.0	6.9	7.8	7.4
	PrecMax	68.1	13.0	9.4	7.4	6.6	4.5	4.6	4.1	8.3	6.3	15.1	13.5	14.0
	PrecMin	41.8	4.1	2.0	2.0	1.5	0.4	0.7	0.1	0.1	0.4	1.6	4.3	4.0
	PrecStd	6.3	2.2	1.7	1.5	1.3	0.9	0.9	0.9	1.9	1.4	3.0	2.1	2.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.2	52.7	52.1	53.7	56.5	61.9	62.3	64.7	63.3	61.1	56.9	53.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	51.2	51.1	50.9	51.8	54.7	58.5	61.4	63.3	62.0	59.6	55.2	52.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	50.2	50.1	49.5	50.5	53.8	57.4	60.3	62.0	61.1	58.4	53.9	51.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	49.4	48.9	48.5	49.5	53.0	56.4	59.3	61.0	60.4	57.5	52.9	49.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Mean Daily Temperature Range	5% DB	MDBR	3.3	3.2	3.5	3.1	2.4	2.3	2.4	2.8	3.0	3.4	3.9	3.6
		MCDBR	3.3	3.5	3.4	3.6	3.3	3.4	3.1	3.9	3.6	4.0	3.9	4.1
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.324	0.330	0.350	0.381	0.387	0.369	0.363	0.366	0.359	0.350	0.331	0.320	
	taud	2.454	2.498	2.458	2.348	2.372	2.464	2.524	2.524	2.526	2.484	2.436	2.400	
	Ebn at Noon	230	260	273	274	277	282	282	277	267	247	223	211	
	Edh at Noon	20	24	29	36	37	34	31	30	27	24	20	18	
All-Sky Solar Radiation	RadAvg	255	539	854	1322	1650	1767	1768	1554	1134	625	312	211	
	RadStd	31	79	98	103	149	167	171	134	86	77	48	27	

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
(47)	Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page