

SOUTH BROOKS BUOY 46132, CanadaWMO: **996960**Lat: **49.740N**Lon: **127.930W**Elev: **3**StdP: **101.29**Time Zone: **-9.00 (W09)**Period: **02-18**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	1.8	3.2	N/A	N/A	N/A	N/A	N/A	N/A	19.8	6.7	18.2	6.9	7.7	340	0.836

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.5	17.0	N/A	16.5	N/A	16.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.5	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.7	15.9	14.2	-0.7	17.8	2.0	1.6	-2.1	19.0	-3.3	19.9	-4.4	20.8	-5.8	22.0
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.2	7.5	7.3	7.1	8.1	9.8	11.8	13.4	14.3	13.9	11.9	9.2	7.7
	DBStd	3.06	1.85	1.80	1.65	1.29	1.42	1.31	1.25	1.29	1.20	1.53	1.97	1.81
	HDD10.0	436	77	77	91	59	22	2	0	0	0	2	34	73
	HDD18.3	2976	335	309	348	308	266	196	153	125	133	199	273	329
	CDD10.0	503	1	1	1	1	14	56	105	133	117	62	11	2
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	7.4	8.3	7.6	7.9	7.2	6.9	6.8	7.1	6.8	6.7	7.4	8.0	8.7
Precipitation	PrecAvg	1395	190	135	120	94	64	57	40	56	76	176	198	189
	PrecMax	1731	331	238	187	167	115	116	103	210	161	383	342	356
	PrecMin	1061	105	51	50	39	10	17	2	3	10	40	110	102
	PrecStd	160	55	44	38	34	23	23	23	49	36	75	53	58
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.2	11.5	11.1	12.1	13.6	16.6	16.8	18.2	17.4	16.2	13.8	12.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	10.7	10.6	10.5	11.0	12.6	14.7	16.4	17.4	16.6	15.3	12.9	11.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	10.1	10.0	9.7	10.3	12.1	14.1	15.7	16.7	16.2	14.7	12.2	10.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	9.7	9.4	9.2	9.7	11.7	13.6	15.2	16.1	15.8	14.2	11.6	10.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	1.8	1.8	2.0	1.7	1.4	1.3	1.3	1.5	1.7	1.9	2.1	2.0
		MCDBR	1.8	1.9	1.9	2.0	1.8	1.9	1.7	2.2	2.0	2.2	2.1	2.3
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.324	0.330	0.350	0.381	0.387	0.369	0.363	0.366	0.359	0.350	0.331	0.320	
	taud	2.454	2.498	2.458	2.348	2.372	2.464	2.524	2.524	2.526	2.484	2.436	2.400	
	Ebn at Noon	724	820	860	864	872	890	890	872	842	780	703	664	
	Edh at Noon	62	75	92	113	116	106	99	94	85	75	63	57	
All-Sky Solar Radiation	RadAvg	0.80	1.70	2.69	4.17	5.20	5.57	5.58	4.90	3.58	1.97	0.98	0.66	
	RadStd	0.10	0.25	0.31	0.33	0.47	0.53	0.54	0.42	0.27	0.24	0.15	0.09	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page