

SOUTH MORESBY BUOY 46147, BC, Canada

WMO: 996980

Lat: 51.830N

Lon: 131.220W

Elev: 10

StdP: 14.69

Time Zone: -8.00 (NAP)

Period: 01-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	31.7	34.9	N/A	N/A	N/A	N/A	N/A	N/A	42.9	44.4	39.6	44.4	19.3	20	0.807

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.5	62.8	N/A	61.7	N/A	60.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	11.7	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 38.5	34.6	31.0	DB	28.3	63.6	5.7	2.6	24.2	65.5	20.8	67.1	17.6	68.5	13.4	70.5	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.2	44.4	43.5	42.9	44.9	48.2	51.9	55.2	57.8	56.5	52.7	47.3	44.9	(6)	
	DBStd	6.00	3.82	3.39	3.65	2.22	2.53	2.79	2.55	2.33	2.44	3.15	3.89	3.46	(7)	
	HDD50	1069	175	181	219	153	67	9	0	0	0	10	95	160	(8)	
	HDD65	5759	639	601	684	602	520	392	304	224	255	382	532	624	(9)	
	CDD50	783	0	0	0	0	12	67	161	241	195	93	13	1	(10)	
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)	
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	15.7	19.7	18.3	17.7	15.6	13.4	12.8	12.3	11.6	12.9	16.2	18.8	19.8	(14)	
(15) Precipitation	PrecAvg	79.9	9.4	7.2	6.6	5.5	4.4	3.2	2.8	4.1	6.1	10.5	9.8	10.3	(15)	
	PrecMax	100.2	14.4	12.6	10.0	8.5	10.7	7.3	5.9	8.7	13.3	15.2	17.3	22.6	(16)	
	PrecMin	62.9	5.1	2.9	2.8	1.7	1.5	1.3	0.6	1.2	1.5	5.3	6.0	4.6	(17)	
	PrecStd	9.5	2.3	2.4	2.0	1.5	2.1	1.5	1.3	1.9	2.4	2.8	2.7	3.8	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.2	50.7	51.0	53.0	55.9	60.7	61.7	63.9	64.3	60.6	57.9	52.3	(19)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(20)	
	2%	DB	50.3	49.5	49.5	50.0	54.5	58.5	60.5	62.8	63.1	59.8	55.9	51.3	(21)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(22)	
	5%	DB	49.5	48.4	48.4	48.8	52.6	57.4	59.8	61.9	61.8	58.7	53.2	50.0	(23)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(24)	
	10%	DB	48.5	47.5	47.4	47.9	51.5	56.1	59.0	61.2	59.9	57.3	51.9	49.0	(25)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(27)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(28)	
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(29)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(30)	
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(31)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(32)	
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(33)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	3.6	3.3	3.8	3.1	2.3	2.3	2.3	2.5	2.9	3.2	3.9	3.7	(35)	
		MCDBR	3.4	3.0	3.4	3.9	3.2	3.3	2.6	3.2	3.0	3.1	3.5	3.5	(36)	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(37)	
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(38)	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.324	0.330	0.358	0.395	0.393	0.376	0.374	0.376	0.376	0.356	0.333	0.316	(40)	
	taud		2.386	2.464	2.386	2.268	2.340	2.444	2.505	2.501	2.451	2.415	2.343	2.344	(41)	
	Ebn at Noon		215	252	265	266	273	279	278	271	256	237	206	195	(42)	
	Edh at Noon		19	23	30	38	37	34	32	30	29	24	20	17	(43)	
(44) All-Sky Solar Radiation	RadAvg		210	486	829	1305	1621	1716	1641	1408	1029	576	282	177	(44)	
	RadStd		26	71	89	64	115	146	153	116	91	61	26	23	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page