

SOUTH MORESBY BUOY 46147, BC, CanadaWMO: **996980**Lat: **51.830N**Lon: **131.220W**Elev: **3**StdP: **101.29**Time Zone: **-8.00 (NAP)**Period: **01-18**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	-0.2	1.6	N/A	N/A	N/A	N/A	N/A	N/A	19.2	6.9	17.7	6.9	8.6	20	0.807

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.4	17.1	N/A	16.5	N/A	16.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.2	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.2	15.5	13.9	-2.0	17.6	3.2	1.5	-4.3	18.6	-6.2	19.5	-8.0	20.3	-10.3	21.4		
(5)			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.6	6.9	6.4	6.1	7.2	9.0	11.1	12.9	14.3	13.6	11.5	8.5	7.2
	DBStd	3.34	2.12	1.89	2.03	1.23	1.41	1.55	1.42	1.29	1.35	1.75	2.16	1.92
	HDD10.0	594	97	101	122	85	37	5	0	0	0	6	53	89
	HDD18.3	3199	355	334	380	334	289	218	169	124	142	212	296	347
	CDD10.0	435	0	0	0	0	7	37	89	134	108	52	7	1
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	7.0	8.8	8.2	7.9	7.0	6.0	5.7	5.5	5.2	5.8	7.2	8.4	8.9
Precipitation	PrecAvg	2030	238	182	167	139	112	82	70	105	155	267	250	262
	PrecMax	2545	365	320	254	215	272	186	150	220	337	387	440	574
	PrecMin	1597	130	74	70	43	38	34	15	31	39	134	153	117
	PrecStd	242	58	62	50	37	53	37	33	47	61	70	68	97
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.7	10.4	10.6	11.7	13.3	15.9	16.5	17.7	17.9	15.9	14.4	11.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	10.2	9.7	9.7	10.0	12.5	14.7	15.8	17.1	17.3	15.4	13.3	10.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	9.7	9.1	9.1	9.3	11.4	14.1	15.5	16.6	16.6	14.8	11.8	10.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	9.2	8.6	8.5	8.8	10.8	13.4	15.0	16.2	15.5	14.1	11.1	9.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	2.0	1.8	2.1	1.7	1.3	1.3	1.3	1.4	1.6	1.8	2.1	2.0
		MCDBR	1.9	1.7	1.9	2.1	1.8	1.8	1.5	1.8	1.7	1.7	1.9	2.0
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.324	0.330	0.358	0.395	0.393	0.376	0.374	0.376	0.376	0.376	0.356	0.333	0.316
	taud	2.386	2.464	2.386	2.268	2.340	2.444	2.505	2.501	2.451	2.415	2.343	2.344	
	Ebn at Noon	679	796	835	840	861	879	875	854	808	746	650	615	
	Edh at Noon	61	74	96	121	118	107	100	95	90	77	63	54	
All-Sky Solar Radiation	RadAvg	0.66	1.53	2.61	4.12	5.11	5.41	5.17	4.44	3.24	1.82	0.89	0.56	
	RadStd	0.08	0.22	0.28	0.20	0.36	0.46	0.48	0.37	0.29	0.19	0.08	0.07	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page