

WEST MAINE SHELF BUOY 44030, ME, USA

WMO: 997150

Lat: 43.179N

Lon: 70.426W

Elev: 0

StdP: 14.70

Time Zone: -5.00 (NAE)

Period: 05-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	11.7	15.2	N/A	N/A	N/A	N/A	N/A	N/A	37.9	26.7	34.4	24.0	19.4	300	0.645

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.3	72.4	N/A	71.0	N/A	69.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	8.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 32.2	27.0	24.7	DB	6.3	76.6	3.1	2.7	4.1	78.6	2.3	80.2	0.5	81.7	-1.7	83.6	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.9	29.8	29.9	34.7	43.2	50.9	59.3	65.2	66.1	61.2	52.8	44.1	36.3
	DBStd	13.90	8.47	6.98	5.99	4.33	4.44	4.33	3.31	2.70	3.82	4.87	6.11	7.12
	HDD50	2555	626	563	474	206	40	1	0	0	0	30	190	425
	HDD65	6353	1091	983	939	653	436	175	38	19	124	378	628	889
	CDD50	1786	0	0	0	3	69	281	471	498	336	117	11	0
	CDD65	109	0	0	0	0	0	4	43	53	9	0	0	0
	CDH74	18	0	0	0	0	1	1	10	6	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	12.7	16.7	16.4	15.1	12.0	10.6	9.4	8.6	9.0	10.3	13.6	15.0	16.2
Precipitation	PrecAvg	50.1	3.6	3.5	4.7	4.4	4.2	4.1	3.9	3.5	4.1	5.5	4.4	4.3
	PrecMax	65.7	6.6	8.6	15.0	9.4	14.1	11.6	8.0	12.5	11.5	14.5	8.4	6.5
	PrecMin	36.1	0.5	1.3	0.7	0.3	0.7	0.7	1.8	0.3	1.6	0.5	1.9	1.6
	PrecStd	8.8	1.3	1.6	3.0	2.2	2.8	2.6	1.8	2.6	2.3	3.8	1.6	1.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.7	45.5	48.2	57.2	65.9	70.8	75.3	74.7	72.1	65.1	57.1	52.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	46.8	42.6	44.8	53.0	62.0	68.2	72.6	72.4	69.4	62.2	54.8	50.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	44.3	41.1	43.1	50.5	59.4	66.3	71.0	71.2	67.9	60.4	53.4	48.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	41.9	39.4	41.5	48.8	57.2	64.7	69.5	70.0	66.3	59.1	52.1	46.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	9.6	9.4	7.7	6.0	5.8	5.7	5.7	5.3	5.4	6.3	7.1	8.5
		MCDBR	9.8	9.0	8.1	8.6	9.0	8.1	7.5	6.4	6.0	6.3	7.1	8.9
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.296	0.304	0.327	0.360	0.397	0.448	0.462	0.431	0.380	0.339	0.318	0.299
	taud		2.487	2.480	2.476	2.422	2.362	2.249	2.219	2.295	2.417	2.526	2.546	2.543
	Ebn at Noon		269	285	291	288	278	263	258	262	269	269	259	258
	Edh at Noon		23	27	30	35	38	43	44	39	32	26	22	20
All-Sky Solar Radiation	RadAvg		535	813	1157	1472	1650	1770	1865	1692	1355	885	581	434
	RadStd		36	64	74	156	181	149	121	78	79	77	50	48

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47) Regional (62 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+153	+59	(47)

Nomenclature: See separate page