

WEST MAINE SHELF BUOY 44030, ME, USA

WMO: 997150

Lat: 43.179N

Lon: 70.426W

Elev: 0

StdP: 101.33

Time Zone: -5.00 (NAE)

Period: 05-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-11.3	-9.4	N/A	N/A	N/A	N/A	N/A	N/A	17.0	-3.0	15.4	-4.5	8.7	300	0.645

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.0	22.5	N/A	21.7	N/A	20.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	3.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.4	12.1	11.0	DB	-14.3	24.8	1.7	1.5	-15.5	25.9	-16.5	26.8	-17.5	27.6	-18.7	28.7	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.8	-1.2	-1.2	1.5	6.2	10.5	15.2	18.4	18.9	16.2	11.6	6.7	2.4
	DBStd	7.72	4.71	3.88	3.33	2.41	2.46	2.40	1.84	1.50	2.12	2.70	3.40	3.96
	HDD10.0	1419	348	313	263	114	22	1	0	0	0	17	106	236
	HDD18.3	3529	606	546	522	363	242	97	21	11	69	210	349	494
	CDD10.0	992	0	0	0	2	38	156	262	277	187	65	6	0
	CDD18.3	61	0	0	0	0	0	2	24	29	5	0	0	0
	CDH23.3	10	0	0	0	0	1	1	6	3	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.7	7.5	7.3	6.7	5.4	4.7	4.2	3.8	4.0	4.6	6.1	6.7	7.2
Precipitation	PrecAvg	1273	91	89	119	111	106	103	98	90	103	140	112	109
	PrecMax	1668	167	218	381	238	358	294	204	318	292	368	213	165
	PrecMin	918	13	33	19	8	17	19	45	7	40	12	47	41
	PrecStd	224	34	41	75	57	72	67	46	65	58	97	41	35
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.9	7.5	9.0	14.0	18.8	21.6	24.1	23.7	22.3	18.4	14.0	11.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	8.2	5.9	7.1	11.7	16.7	20.1	22.6	22.4	20.8	16.8	12.7	10.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	6.9	5.0	6.2	10.3	15.2	19.1	21.7	21.8	20.0	15.8	11.9	9.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	5.5	4.1	5.3	9.4	14.0	18.1	20.8	21.1	19.1	15.1	11.2	8.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	5.3	5.2	4.3	3.4	3.2	3.2	3.0	3.0	3.5	4.0	4.7	
		MCDBR	5.4	5.0	4.5	4.8	5.0	4.5	4.2	3.5	3.4	3.5	4.0	4.9
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.296	0.304	0.327	0.360	0.397	0.448	0.462	0.431	0.380	0.339	0.318	0.299
	taud		2.487	2.480	2.476	2.422	2.362	2.249	2.219	2.295	2.417	2.526	2.546	2.543
	Ebn at Noon		847	900	918	907	877	829	812	826	848	848	815	812
	Edh at Noon		71	85	96	110	120	135	138	124	102	81	68	63
All-Sky Solar Radiation	RadAvg		1.69	2.56	3.65	4.64	5.20	5.58	5.88	5.33	4.27	2.79	1.83	1.37
	RadStd		0.11	0.20	0.23	0.49	0.57	0.47	0.38	0.25	0.25	0.24	0.16	0.15

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (62 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
										+85	+33

Nomenclature: See separate page