

C MAINE SHELF BUOY 44032, ME, USAWMO: **997170**Lat: **43.715N**Lon: **69.355W**Elev: **0**StdP: **14.70**Time Zone: **-5.00 (NAE)**Period: **06-18**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	10.6	14.6	N/A	N/A	N/A	N/A	N/A	N/A	37.6	31.2	35.4	28.4	20.2	310	0.683

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.6	69.4	N/A	68.3	N/A	67.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	8.7	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 33.6	30.7	26.2	6.4	72.7	2.3	2.4	4.8	74.4	3.4	75.7	2.1	77.1	0.4	78.8		
(5)			DB													
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.1	30.5	29.8	34.6	42.3	49.0	56.2	62.9	63.6	59.9	52.8	45.0	37.0	
	DBStd	12.93	8.84	7.21	5.90	3.53	3.62	3.42	3.28	2.73	3.21	4.38	6.24	7.81	
	HDD50	2538	603	566	477	231	64	0	0	0	0	26	167	404	
	HDD65	6580	1068	986	942	681	495	264	79	61	155	380	601	868	
	CDD50	1463	0	0	0	0	33	186	399	421	297	111	16	0	
	CDD65	31	0	0	0	0	0	0	13	16	2	0	0	0	
	CDH74	1	0	0	0	0	0	0	1	0	0	0	0	0	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	13.3	18.3	17.6	16.7	12.5	10.4	8.9	8.4	8.5	10.4	14.4	16.2	17.8	
Precipitation	PrecAvg	48.8	3.9	3.5	4.7	4.2	3.8	3.7	3.5	3.0	4.3	4.8	4.8	4.5	
	PrecMax	70.2	7.1	7.5	8.3	8.6	8.6	8.8	7.0	7.8	9.5	15.1	8.5	7.6	
	PrecMin	34.3	0.6	2.0	0.9	0.5	1.0	1.3	1.5	0.4	1.7	0.9	2.2	1.7	
	PrecStd	8.7	1.7	1.2	2.0	2.0	1.8	2.1	1.7	1.9	2.2	3.0	1.5	1.4	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.4	45.2	46.0	52.9	59.8	66.0	71.5	71.4	68.9	62.4	57.2	53.2	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	47.9	43.1	44.2	49.7	57.7	63.8	69.3	69.9	67.1	60.3	55.0	51.0	N/A
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	45.7	41.4	42.7	48.2	55.9	62.1	68.2	68.6	65.7	59.2	53.8	49.5	N/A
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	43.2	39.8	41.5	47.0	54.2	60.5	67.1	67.5	64.3	58.0	52.9	47.9	N/A
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range		MDBR	10.3	9.4	7.5	5.0	4.8	4.9	5.0	4.6	4.5	5.1	6.4	9.3	
	5% DB	MCDBR	10.0	9.3	7.1	6.5	7.0	6.7	6.3	5.5	5.1	4.6	5.4	9.8	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.307	0.313	0.332	0.357	0.386	0.429	0.448	0.416	0.373	0.343	0.322	0.302		
	taud	2.463	2.465	2.462	2.428	2.393	2.288	2.255	2.336	2.429	2.508	2.532	2.523		
	Ebn at Noon	261	281	288	288	281	268	261	266	271	266	254	254		
	Edh at Noon	23	27	31	35	37	41	42	38	32	26	22	20		
All-Sky Solar Radiation	RadAvg	502	793	1172	1482	1679	1797	1899	1713	1373	890	555	405		
	RadStd	35	61	75	155	193	151	126	83	81	80	50	46		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (39 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+130	N/A	

Nomenclature: See separate page