

JORDAN BASIN BUOY 44037, USA

WMO: 997183

Lat: 43.497N

Lon: 67.876W

Elev: 0

StdP: 14.70

Time Zone: -5.00 (W05)

Period: 06-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	15.9	19.0	N/A	N/A	N/A	N/A	N/A	N/A	43.8	32.9	39.2	31.1	23.2	340	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.9	70.4	N/A	68.7	N/A	67.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	9.9	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 36.6	33.6	30.7	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.1	33.7	33.0	36.4	41.9	48.0	55.3	62.8	64.4	60.9	53.6	46.4	39.5		
	DBStd	11.93	8.09	6.38	5.13	3.01	3.35	3.53	3.07	2.92	3.53	4.32	5.71	7.10		
	HDD50	2204	506	475	423	242	83	2	0	0	0	19	129	325		
	HDD65	6221	970	895	888	692	527	291	82	46	132	352	557	789		
	CDD50	1508	0	0	0	0	21	162	396	448	326	132	22	1		
	CDD65	51	0	0	0	0	0	0	13	29	9	0	0	0		
	CDH74	23	0	0	0	0	0	1	4	12	6	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	15.2	20.1	19.8	18.8	14.7	12.2	10.9	10.3	10.5	12.1	16.0	17.3	19.7		
(15) Precipitation	PrecAvg	60.8	5.7	4.8	5.3	4.9	4.4	4.9	3.8	3.8	4.7	5.9	5.7	7.0		
	PrecMax	82.2	10.5	10.3	8.9	9.8	8.7	10.0	7.6	9.2	9.9	16.5	9.8	11.6		
	PrecMin	37.9	1.2	2.0	1.6	0.6	0.8	2.4	1.8	1.1	1.6	1.5	2.2	2.6		
	PrecStd	8.6	2.1	1.6	1.9	2.0	1.9	2.0	1.5	2.0	2.1	2.9	1.7	2.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.8	48.4	48.7	50.7	57.9	66.0	72.2	76.3	74.2	63.3	57.5	54.1		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	49.4	46.2	46.4	48.1	56.1	62.9	68.7	71.4	68.4	61.2	55.8	52.3		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	47.2	44.2	44.3	46.9	54.5	61.4	67.5	69.4	66.9	60.2	54.4	50.7		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	45.1	42.1	42.7	45.9	52.9	60.0	66.5	68.3	65.2	59.2	53.3	49.3		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.5	8.3	6.0	4.1	4.0	4.1	4.0	3.9	4.2	4.6	5.6	8.1		
		MCDBR	9.3	11.4	7.1	5.3	5.7	6.3	5.9	6.1	7.0	4.9	5.5	9.9		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.320	0.322	0.342	0.364	0.387	0.423	0.446	0.418	0.373	0.348	0.330	0.315		
	taud		2.459	2.484	2.458	2.422	2.402	2.314	2.274	2.336	2.432	2.502	2.511	2.496		
	Ebn at Noon		257	278	285	286	281	270	262	266	271	265	252	248		
	Edh at Noon		23	27	31	35	36	40	42	38	32	26	22	21		
(44) All-Sky Solar Radiation	RadAvg		433	728	1151	1506	1707	1852	1911	1725	1407	918	530	365		
	RadStd		37	62	90	156	206	167	136	85	83	88	58	43		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (22 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+119	N/A	N/A

Nomenclature: See separate page