

JORDAN BASIN BUOY 44037, USA

WMO: 997183

Lat: 43.497N

Lon: 67.876W

Elev: 0

StdP: 101.33

Time Zone: -5.00 (W05)

Period: 06-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 2	(b) -9.0	(c) -7.2	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 19.6	(k) 0.5	(l) 17.5	(m) -0.5	(n) 10.4	(o) 340	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 2.2	(c) 21.3	(d) N/A	(e) 20.4	(f) N/A	(g) 19.7	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 4.4	(p) 200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 16.4	(b) 15.0	(c) 13.7	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.9	0.9	0.6	2.4	5.5	8.9	13.0	17.1	18.0	16.0	12.0	8.0	4.2
	DBStd	6.63	4.50	3.55	2.85	1.67	1.86	1.96	1.71	1.62	1.96	2.40	3.17	3.94
	HDD10.0	1224	281	264	235	134	46	1	0	0	0	11	72	181
	HDD18.3	3456	539	497	493	384	293	162	46	26	73	196	309	438
	CDD10.0	838	0	0	0	0	12	90	220	249	181	73	12	1
	CDD18.3	28	0	0	0	0	0	0	7	16	5	0	0	0
	CDH23.3	13	0	0	0	0	0	1	2	7	3	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	6.8	9.0	8.8	8.4	6.6	5.5	4.9	4.6	4.7	5.4	7.2	7.8	8.8
Precipitation	PrecAvg	1544	144	122	134	124	111	124	96	97	120	150	145	177
	PrecMax	2087	266	262	227	249	222	254	192	234	251	420	248	295
	PrecMin	963	31	51	41	16	21	62	45	27	41	39	55	67
	PrecStd	219	53	41	49	51	47	52	39	51	53	73	43	56
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.0	9.1	9.3	10.4	14.4	18.9	22.3	24.6	23.4	17.4	14.1	12.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	9.6	7.9	8.0	9.0	13.4	17.2	20.4	21.9	20.2	16.2	13.2	11.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	8.4	6.8	6.8	8.3	12.5	16.3	19.7	20.8	19.4	15.7	12.4	10.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	7.3	5.6	5.9	7.7	11.6	15.5	19.2	20.1	18.5	15.1	11.8	9.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	4.7	4.6	3.3	2.3	2.2	2.3	2.2	2.2	2.3	2.6	3.1	4.5
		MCDBR	5.2	6.3	3.9	2.9	3.2	3.5	3.3	3.4	3.9	2.7	3.1	5.5
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.320	0.322	0.342	0.364	0.387	0.423	0.446	0.418	0.373	0.348	0.330	0.315
	taud		2.459	2.484	2.458	2.422	2.402	2.314	2.274	2.336	2.432	2.502	2.511	2.496
	Ebn at Noon		810	877	900	902	886	851	825	838	854	834	793	782
	Edh at Noon		74	85	98	110	115	127	131	119	100	82	70	65
All-Sky Solar Radiation	RadAvg		1.37	2.29	3.63	4.75	5.38	5.84	6.02	5.44	4.43	2.89	1.67	1.15
	RadStd		0.12	0.20	0.28	0.49	0.65	0.53	0.43	0.27	0.26	0.28	0.18	0.14

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (22 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+66	N/A

Nomenclature: See separate page