

SOUTH SANTA ROSA ISLAND, CA, USA

WMO: 997199

Lat: 33.677N

Lon: 120.213W

Elev: 10

StdP: 14.69

Time Zone: -8.00 (W08)

Period: 05-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	49.7	50.6	N/A	N/A	N/A	N/A	N/A	N/A	36.3	53.0	34.9	52.9	18.1	330	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	2.6	68.9	N/A	67.8	N/A	66.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	12.0	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 32.9	31.2	29.6	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	57.7	56.2	55.2	55.1	54.6	55.6	56.8	59.8	60.6	61.5	61.1	59.2	56.7		
	DBStd	3.66	2.88	2.62	2.61	2.12	2.41	2.01	3.21	2.67	3.17	3.25	2.70	2.66		
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD65	2687	272	275	308	311	292	247	165	139	116	131	174	257		
	CDD50	2816	193	145	158	140	173	203	303	327	345	344	277	208		
	CDD65	25	0	0	0	0	1	0	3	1	10	9	1	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	16.2	14.0	15.0	16.1	18.3	19.1	18.3	16.4	17.1	16.6	14.8	14.8	14.4		
(15) Precipitation	PrecAvg	14.0	2.8	3.0	2.1	1.1	0.6	0.2	0.1	0.1	0.2	0.7	1.2	2.2		
	PrecMax	28.4	12.2	12.9	9.7	3.8	2.4	0.7	0.5	0.4	0.7	3.3	3.9	7.2		
	PrecMin	4.6	0.2	0.2	0.0	0.2	0.1	0.0	0.0	0.0	0.0	0.1	0.2	0.2		
	PrecStd	5.6	2.6	2.6	2.1	0.9	0.5	0.2	0.1	0.1	0.1	0.7	0.9	1.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	65.4	64.8	64.2	62.4	65.5	66.3	68.4	67.7	71.0	70.5	67.4	64.3		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	63.1	61.4	61.4	59.3	61.0	61.4	67.2	66.1	69.3	68.5	65.2	63.4		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	61.6	59.9	59.8	58.2	59.6	60.1	66.0	65.3	68.0	67.7	63.9	62.2		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	60.3	58.7	58.9	57.4	58.7	59.3	64.8	64.4	66.4	66.4	62.8	60.7		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	3.3	2.9	2.8	2.6	2.5	2.6	2.6	2.4	2.6	2.8	3.0	2.8		
		MCDBR	5.0	4.1	3.8	3.5	3.8	3.3	3.0	2.8	3.2	4.0	4.6	3.3		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.305	0.316	0.329	0.351	0.358	0.347	0.368	0.351	0.345	0.345	0.309	0.309		
	taud		2.625	2.609	2.561	2.480	2.484	2.514	2.509	2.526	2.550	2.551	2.628	2.623		
	Ebn at Noon		292	299	301	297	294	296	289	293	292	284	287	284		
	Edh at Noon		24	27	30	35	35	34	34	33	30	28	24	23		
(44) All-Sky Solar Radiation	RadAvg		990	1259	1652	2026	2082	1984	1842	1755	1635	1322	1079	893		
	RadStd		69	107	110	129	219	129	139	152	144	152	75	75		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (26 neighbors)		+1.15	N/A	-2.57	+1.53	N/A	N/A	N/A	-239	+432	+151	

Nomenclature: See separate page