

NEW DUNGENESS BUOY 46088, WA, USA

WMO: 997207

Lat: 48.332N

Lon: 123.179W

Elev: 10

StdP: 14.69

Time Zone: -8.00 (NAP)

Period: 05-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 30.3	(c) 34.4	(d) 14.8	(e) 11.6	(f) 33.2	(g) 19.5	(h) 14.6	(i) 37.5	(j) 38.9	(k) 43.3	(l) 36.8	(m) 44.0	(n) 15.5	(o) 20	(p) 0.700

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 5.5	(c) 62.8	(d) 57.0	(e) 60.0	(f) 55.5	(g) 58.3	(h) 54.8	(i) 57.6	(j) 60.8	(k) 56.4	(l) 58.9	(m) 55.5	(n) 57.4	(o) 4.9	(p) 230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
56.0	66.7	58.4	55.1	64.6	57.3	54.3	62.8	56.6	24.8	61.1	24.0	59.4	23.5	57.9	65.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
33.6	29.9	24.7	27.3	70.7	5.2	2.6	23.6	72.5	20.5	74.0	17.6	75.5	13.8	77.3
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.1	43.5	44.1	45.5	47.3	50.5	53.1	54.9	55.2	54.3	51.0	46.3	43.6	(6)
	DBStd	5.30	3.62	3.62	3.00	2.53	2.21	2.12	2.45	1.96	2.14	2.27	4.18	4.30	(7)
	HDD50	950	202	167	141	87	18	1	0	0	0	16	117	201	(8)
	HDD65	5791	667	586	604	532	448	358	313	302	322	433	561	665	(9)
	CDD50	635	0	1	2	5	35	94	152	163	128	48	6	1	(10)
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14) Wind	WSAvg	11.1	11.9	11.5	11.1	11.6	11.3	11.7	12.3	10.9	7.8	8.3	11.7	13.3	(14)
(15) Precipitation	PrecAvg	28.8	4.3	2.8	2.6	1.7	1.3	1.0	0.6	0.9	1.1	3.1	5.2	4.3	(15)
	PrecMax	38.6	7.6	6.9	5.1	3.3	2.7	2.3	1.4	2.5	4.5	7.6	11.6	6.8	(16)
	PrecMin	19.0	1.6	0.1	0.9	0.4	0.2	0.3	0.2	0.1	0.0	0.6	1.4	1.9	(17)
	PrecStd	5.0	1.6	1.5	1.0	0.8	0.7	0.5	0.4	0.7	0.9	1.7	2.6	1.3	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.5	52.2	53.9	55.6	60.2	64.3	67.9	66.1	63.9	57.5	55.1	53.2	(19)
		MCWB	47.2	49.0	48.3	50.9	52.3	57.2	60.7	59.6	57.3	52.7	52.1	50.3	(20)
	2%	DB	50.0	50.6	51.3	52.9	56.5	58.6	62.6	61.5	60.5	55.8	53.2	51.1	(21)
		MCWB	47.2	47.6	48.1	49.1	51.5	54.4	57.1	57.1	55.6	52.1	50.7	48.2	(22)
	5%	DB	48.6	49.4	50.2	51.4	54.4	56.7	59.3	59.1	58.6	54.6	51.6	49.9	(23)
		MCWB	46.3	46.8	47.1	48.1	50.8	53.3	55.4	55.7	54.8	51.6	49.2	47.3	(24)
	10%	DB	47.6	48.3	49.1	50.4	53.2	55.4	57.4	57.6	57.0	53.5	50.5	48.7	(25)
		MCWB	45.3	45.6	46.3	47.2	50.3	52.4	54.5	55.0	54.1	51.1	48.2	46.2	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.4	49.8	50.2	51.5	54.4	58.3	61.6	59.2	58.2	54.9	53.1	51.1	(27)
		MCDB	50.0	50.8	51.4	54.2	57.7	63.1	66.6	62.9	62.1	56.2	54.3	52.5	(28)
	2%	WB	48.0	48.3	48.7	50.3	52.9	55.6	57.8	57.3	56.6	53.4	51.6	49.2	(29)
		MCDB	49.2	49.4	50.0	52.7	55.4	58.4	61.5	59.5	59.4	54.4	53.0	50.7	(30)
	5%	WB	46.9	47.3	47.8	49.2	51.6	54.3	56.1	56.3	55.5	52.5	50.3	48.0	(31)
		MCDB	48.3	48.5	49.2	51.3	53.7	56.4	58.8	58.2	57.3	53.7	51.4	49.6	(32)
	10%	WB	45.9	45.7	46.9	48.0	50.9	53.2	55.1	55.5	54.8	51.8	49.1	46.8	(33)
		MCDB	47.4	47.1	48.5	50.0	52.9	54.9	57.4	57.0	56.6	53.0	50.2	48.6	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	3.9	3.9	4.6	4.5	4.6	4.8	5.4	5.5	5.5	4.1	4.0	3.9	(35)
		MCDBR	5.0	4.9	5.6	5.5	6.4	7.0	8.8	8.1	8.3	5.3	4.7	4.7	(36)
	5% WB	MCWBR	3.9	3.9	3.9	3.3	3.7	4.2	5.5	4.6	4.8	3.3	4.1	3.8	(37)
		MCDWR	4.2	3.8	4.7	5.4	5.7	7.4	8.1	6.9	6.7	4.6	4.8	4.4	(38)
(40) Clear-Sky Solar Irradiance	taub		0.320	0.321	0.333	0.359	0.380	0.359	0.350	0.355	0.341	0.334	0.329	0.317	(40)
		taud	2.519	2.536	2.518	2.441	2.397	2.480	2.537	2.522	2.558	2.562	2.495	2.477	(41)
	Ebn at Noon		240	268	282	283	280	286	287	281	276	259	233	224	(42)
		Edh at Noon	20	23	28	33	36	33	31	30	27	23	20	18	(43)
(44) All-Sky Solar Radiation	RadAvg		298	577	898	1353	1728	1889	2069	1748	1249	689	355	240	(44)
	RadStd		40	77	105	126	136	180	146	114	104	75	53	32	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (73 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page