

NEW DUNGENESS BUOY 46088, WA, USA

WMO: 997207

Lat: 48.332N

Lon: 123.179W

Elev: 3

StdP: 101.29

Time Zone: -8.00 (NAP)

Period: 05-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.9	1.3	-9.6	1.7	0.7	-7.0	2.1	3.1	17.4	6.3	16.4	6.7	6.9	20	0.700

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.1	17.1	13.9	15.5	13.1	14.6	12.7	14.2	16.0	13.6	14.9	13.0	14.1	2.2	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.3	9.5	14.7	12.8	9.2	14.1	12.4	9.0	13.7	39.7	16.2	38.0	15.2	36.8	14.4	18.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
15.0	13.4	11.0	DB	-2.6	21.5	2.9	1.4	-4.7	22.5	-6.4	23.3	-8.0	24.2	-10.1	25.2	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.5	6.4	6.7	7.5	8.5	10.3	11.7	12.7	12.9	12.4	10.6	7.9	6.4
	DBStd	2.95	2.01	2.01	1.67	1.41	1.23	1.18	1.36	1.09	1.19	1.26	2.32	2.39
	HDD10.0	528	112	93	78	48	10	1	0	0	0	9	65	112
	HDD18.3	3217	371	326	336	296	249	199	174	168	179	241	312	369
	CDD10.0	353	0	1	1	3	19	52	84	91	71	27	3	1
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.0	5.3	5.1	5.0	5.2	5.0	5.2	5.5	4.9	3.5	3.7	5.2	5.9
Precipitation	PrecAvg	731	109	71	66	44	33	25	15	22	27	78	131	109
	PrecMax	981	193	176	130	85	69	59	36	64	114	192	294	172
	PrecMin	482	40	3	23	11	4	7	4	3	0	15	35	49
	PrecStd	128	40	38	25	20	18	12	9	17	23	42	67	34
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.8	11.2	12.2	13.1	15.7	18.0	20.0	18.9	17.7	14.2	12.8	11.8
		MCWB	8.5	9.5	9.0	10.5	11.3	14.0	16.0	15.3	14.1	11.5	11.2	10.1
	2%	DB	10.0	10.4	10.7	11.6	13.6	14.8	17.0	16.4	15.9	13.2	11.8	10.6
		MCWB	8.4	8.7	8.9	9.5	10.8	12.5	14.0	13.9	13.1	11.2	10.4	9.0
	5%	DB	9.2	9.7	10.1	10.8	12.5	13.7	15.1	15.1	14.8	12.6	10.9	9.9
		MCWB	8.0	8.2	8.4	8.9	10.5	11.9	13.0	13.2	12.7	10.9	9.5	8.5
	10%	DB	8.6	9.0	9.5	10.2	11.8	13.0	14.1	14.2	13.9	12.0	10.3	9.3
		MCWB	7.4	7.6	7.9	8.5	10.2	11.3	12.5	12.8	12.3	10.6	9.0	7.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.6	9.9	10.1	10.8	12.5	14.6	16.4	15.1	14.6	12.7	11.7	10.6
		MCDB	10.0	10.4	10.8	12.3	14.3	17.3	19.2	17.1	16.7	13.4	12.4	11.4
	2%	WB	8.9	9.1	9.3	10.2	11.6	13.1	14.4	14.0	13.7	11.9	10.9	9.6
		MCDB	9.5	9.7	10.0	11.5	13.0	14.7	16.4	15.3	15.2	12.4	11.6	10.4
	5%	WB	8.3	8.5	8.8	9.6	10.9	12.4	13.4	13.5	13.0	11.4	10.2	8.9
		MCDB	9.1	9.2	9.6	10.7	12.1	13.6	14.9	14.5	14.1	12.0	10.8	9.8
	10%	WB	7.7	7.6	8.3	8.9	10.5	11.8	12.8	13.0	12.7	11.0	9.5	8.2
		MCDB	8.6	8.4	9.2	10.0	11.6	12.7	14.1	13.9	13.7	11.7	10.1	9.2
Mean Daily Temperature Range	5% DB	MDBR	2.2	2.2	2.5	2.5	2.5	2.7	3.0	3.1	3.0	2.3	2.2	2.2
		MCDBR	2.8	2.7	3.1	3.1	3.6	3.9	4.9	4.5	4.6	2.9	2.6	2.6
		MCWBR	2.2	2.2	2.1	1.8	2.1	2.4	3.0	2.5	2.7	1.8	2.3	2.1
	5% WB	MCDBR	2.3	2.1	2.6	3.0	3.2	4.1	4.5	3.8	3.7	2.6	2.7	2.5
		MCWBR	2.2	1.9	2.1	1.8	2.2	2.9	3.1	2.6	2.5	2.0	2.5	2.2
Clear-Sky Solar Irradiance	taub	0.320	0.321	0.333	0.359	0.380	0.359	0.350	0.355	0.341	0.334	0.329	0.317	
	taud	2.519	2.536	2.518	2.441	2.397	2.480	2.537	2.522	2.558	2.562	2.495	2.477	
	Ebn at Noon	758	845	889	893	882	903	906	887	869	818	733	705	
	Edh at Noon	62	74	88	104	114	105	98	95	84	72	62	57	
All-Sky Solar Radiation	RadAvg	0.94	1.82	2.83	4.27	5.45	5.96	6.52	5.51	3.94	2.17	1.12	0.76	
	RadStd	0.13	0.24	0.33	0.40	0.43	0.57	0.46	0.36	0.33	0.24	0.17	0.10	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (73 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page