

OSWEGO HARBOR, NY, USA

WMO: 997264

Lat: 43.464N

Lon: 76.511W

Elev: 256

StdP: 14.56

Time Zone: -5.00 (NAE)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 2.6	(c) 7.3	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 53.7	(k) 21.9	(l) 44.1	(m) 26.2	(n) 14.5	(o) 150	(p) 0.613

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 11.2	(c) 84.5	(d) N/A	(e) 81.9	(f) N/A	(g) 79.6	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 11.2	(p) 170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 39.1	(b) 32.9	(c) 27.7	(e) DB	(f) -2.1	(g) 90.0	(h) 4.4	(i) 2.5	(j) -5.2	(k) 91.8	(l) -7.8	(m) 93.3	(n) -10.3	(o) 94.7	(p) -13.5	(q) 96.5	(r) N/A
(4) 39.1	(5) 32.9	(6) 27.7	(7) DB	(8) -2.1	(9) 90.0	(10) 4.4	(11) 2.5	(12) -5.2	(13) 91.8	(14) -7.8	(15) 93.3	(16) -10.3	(17) 94.7	(18) -13.5	(19) 96.5	(20) N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.7	24.5	25.9	33.4	45.5	55.9	65.2	71.4	69.9	63.4	52.7	42.1	32.9
	DBStd	17.98	11.06	8.77	9.08	8.29	8.14	6.54	4.77	4.18	6.50	6.84	8.00	8.52
	HDD50	3040	792	676	519	184	30	0	0	0	47	259	533	
	HDD65	6485	1255	1096	979	588	304	77	6	7	106	384	688	995
	CDD50	2563	2	1	5	50	212	456	664	618	401	132	20	2
	CDD65	533	0	0	0	4	21	82	205	160	57	4	0	0
	CDH74	2518	0	0	0	32	120	413	1003	649	285	16	0	0
	CDH80	447	0	0	0	5	20	79	175	102	64	2	0	0
(14) Wind	WSAvg	12.3	14.8	14.7	14.9	13.5	10.6	10.3	9.5	10.0	10.0	11.8	12.6	15.3
(15) Precipitation	PrecAvg	43.2	3.7	3.1	3.2	3.5	3.5	3.4	2.8	3.6	4.0	3.8	4.6	3.9
	PrecMax	54.6	8.9	6.8	5.6	6.4	6.7	7.1	9.4	7.9	8.2	8.1	8.8	6.5
	PrecMin	31.2	1.6	0.7	1.1	0.9	1.0	1.0	0.6	1.3	0.9	0.2	1.8	1.7
	PrecStd	5.5	1.5	1.3	1.1	1.5	1.5	1.5	1.7	1.3	1.5	1.7	1.4	1.1
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.0	56.1	63.9	78.9	82.8	86.0	88.0	86.2	87.1	76.0	66.8	58.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	50.3	47.8	57.3	70.5	77.5	82.2	84.3	82.5	80.9	70.3	61.6	52.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	44.0	41.8	52.1	64.2	73.0	78.8	81.7	80.1	76.9	66.4	58.1	48.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	39.1	37.4	45.9	58.8	68.9	75.4	79.3	77.5	73.5	63.1	53.6	44.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	5% DB	MDBR	12.3	11.2	11.2	13.1	13.9	11.8	11.2	11.6	12.9	11.3	10.8	10.1
		MCDBR	17.3	17.3	18.8	24.4	21.0	18.1	14.9	15.8	16.7	16.1	16.8	14.3
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub		0.298	0.306	0.326	0.362	0.390	0.429	0.432	0.421	0.376	0.353	0.313	0.289
	taud		2.419	2.389	2.410	2.376	2.355	2.277	2.276	2.294	2.403	2.449	2.514	2.505
	Ebn at Noon		265	283	290	286	280	268	266	265	270	262	259	260
	Edh at Noon		24	29	32	36	38	42	41	39	33	28	22	20
(44) All-Sky Solar Radiation	RadAvg		381	629	1033	1418	1752	1854	1888	1676	1321	779	475	294
	RadStd		42	60	86	156	167	152	154	84	112	73	64	44

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (28 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+130	N/A

Nomenclature: See separate page