

ATLANTIC CITY BOARDWALK, NJ, USA

WMO: 997270

Lat: 39.357N

Lon: 74.418W

Elev: 33

StdP: 14.68

Time Zone: -5.00 (NAE)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 14.1	(c) 18.4	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 25.4	(k) 31.4	(l) 23.4	(m) 30.6	(n) 2.8	(o) 350	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 8.4	(c) 86.2	(d) N/A	(e) 82.8	(f) N/A	(g) 80.2	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 6.7	(p) 240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 24.3	(b) 20.6	(c) 18.0	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	55.3	34.2	36.8	41.6	51.1	60.1	69.5	75.1	74.6	69.8	60.0	48.8	41.4		
	DBStd	15.69	9.29	7.83	7.00	6.50	5.47	5.25	4.01	3.48	4.87	6.34	7.29	8.12		
	HDD50	1595	491	372	273	62	1	0	0	0	0	6	108	282		
	HDD65	4491	954	790	727	422	170	17	0	0	15	179	487	730		
	CDD50	3544	2	2	11	94	314	586	779	761	593	314	71	17		
	CDD65	965	0	0	0	4	18	153	314	296	158	22	0	0		
	CDH74	3965	0	0	0	17	26	528	1632	1350	385	27	0	0		
	CDH80	640	0	0	0	1	2	119	308	177	30	3	0	0		
(14) Wind	WSAvg	5.2	4.8	5.1	6.2	6.8	5.1	4.4	3.5	4.2	4.7	6.3	6.3	5.6		
(15) Precipitation	PrecAvg	40.4	3.3	2.9	3.9	3.5	3.2	2.8	3.7	4.3	3.1	3.0	3.3	3.3		
	PrecMax	56.5	8.4	6.3	8.5	7.5	6.8	8.2	12.5	16.6	6.9	9.6	8.5	6.9		
	PrecMin	25.6	0.4	0.6	0.3	0.9	0.3	0.7	0.6	1.0	0.2	0.0	0.9	0.7		
	PrecStd	5.8	1.6	1.2	1.9	1.7	1.7	1.7	2.2	3.0	1.7	1.9	2.0	1.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.3	58.7	63.8	76.5	77.9	88.3	91.4	88.5	83.6	77.5	65.3	60.5		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	51.3	52.2	57.4	68.7	73.2	83.3	86.9	84.9	79.4	72.4	62.4	57.4		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	48.8	48.2	53.6	63.1	70.0	79.6	83.1	81.2	77.5	70.6	60.5	55.2		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	46.3	46.0	50.8	59.4	67.7	76.4	80.4	79.2	76.3	68.9	59.0	52.9		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.0	11.0	10.6	10.4	9.3	9.1	8.4	7.5	7.7	9.5	10.4	10.2		
		MCDBR	12.7	13.0	15.2	17.1	13.5	15.3	13.4	11.7	9.3	11.3	10.7	10.3		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.318	0.323	0.355	0.387	0.433	0.488	0.498	0.491	0.411	0.365	0.333	0.318		
	taud		2.500	2.489	2.432	2.366	2.270	2.157	2.140	2.152	2.350	2.482	2.521	2.539		
	Ebn at Noon		271	286	286	282	270	254	250	249	264	267	263	263		
	Edh at Noon		24	28	33	38	43	48	48	46	36	28	24	22		
(44) All-Sky Solar Radiation	RadAvg		634	921	1247	1599	1781	1951	1974	1741	1424	1024	727	562		
	RadStd		56	100	102	124	208	165	98	120	130	99	67	54		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (58 neighbors)		+0.77	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+227	+131

Nomenclature: See separate page