

CONIMUCUT LIGHT, RI, USA

WMO: 997277

Lat: 41.7170N

Lon: 71.3451W

Elev: 10

StdP: 101.20

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -11.6	(c) -9.2	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 22.2	(k) -4.4	(l) 19.3	(m) -4.7	(n) 9.6	(o) 290	(p) 0.640

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 5.8	(c) 29.1	(d) N/A	(e) 27.6	(f) N/A	(g) 26.5	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 5.4	(p) 270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 17.1	(b) 14.2	(c) 12.0	(e) -14.0	(f) 32.3	(g) 2.5	(h) 2.2	(i) -15.8	(j) 33.9	(k) -17.3	(l) 35.2	(m) -18.7	(n) 36.5	(o) -20.5	(p) 38.1		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.2	-0.9	-0.1	3.5	9.4	14.1	19.3	23.6	22.2	18.7	13.3	7.7	2.8		
	DBStd	9.06	4.96	4.33	4.01	3.20	3.36	3.19	2.11	2.17	2.80	3.50	4.01	4.38		
	HDD10.0	1205	337	282	204	48	4	0	0	0	0	11	91	228		
	HDD18.3	2993	595	516	459	269	137	25	0	1	29	159	320	483		
	CDD10.0	1644	0	0	3	29	132	281	422	378	262	113	21	3		
	CDD18.3	390	0	0	0	6	56	164	121	41	3	0	0	0		
	CDH23.3	1662	0	0	0	3	21	190	877	483	82	5	0	0		
	CDH26.7	246	0	0	0	0	3	34	156	49	3	0	0	0		
(14) Wind	WSAvg	5.8	6.6	6.5	7.1	6.7	5.7	5.3	4.9	4.7	5.0	5.5	5.7	5.8		
(15) Precipitation	PrecAvg	1154	100	88	109	102	91	83	74	94	98	96	108	110		
	PrecMax	1715	296	183	224	324	213	281	205	256	201	391	280	273		
	PrecMin	646	13	10	14	38	18	4	10	18	23	10	10	26		
	PrecStd	193	55	37	52	52	45	57	41	55	49	70	53	58		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.7	10.8	16.4	21.9	25.8	30.2	31.8	31.0	26.9	23.8	17.9	15.0		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	9.7	9.0	12.5	17.6	22.5	27.2	29.9	27.9	25.4	21.2	15.9	12.7		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	7.9	7.1	10.4	15.4	20.6	25.4	28.3	26.7	24.2	19.6	14.7	11.2		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	6.0	5.7	8.9	14.0	19.1	23.9	27.0	25.8	23.1	18.4	13.6	9.5		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.4	6.4	6.2	6.2	6.3	6.1	5.8	5.8	6.1	6.0	5.9	5.6		
		MCDBR	8.8	7.4	7.8	8.3	8.2	7.9	6.9	6.6	6.4	6.5	6.2	7.0		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.299	0.308	0.333	0.372	0.413	0.460	0.484	0.441	0.374	0.339	0.312	0.299		
	taud		2.502	2.483	2.464	2.384	2.301	2.209	2.151	2.261	2.423	2.530	2.565	2.560		
	Ebn at Noon		858	905	918	898	864	821	796	822	861	857	838	830		
	Edh at Noon		73	86	99	115	129	142	149	129	102	82	69	64		
(44) All-Sky Solar Radiation	RadAvg		1.86	2.73	3.74	4.82	5.33	5.82	6.01	5.40	4.39	2.95	2.02	1.55		
	RadStd		0.14	0.26	0.27	0.52	0.54	0.57	0.33	0.28	0.32	0.27	0.15	0.15		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (68 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+95	+47

Nomenclature: See separate page