

NEW YORK KINGS POINT, NY, USA

WMO: 997280

Lat: 40.811N

Lon: 73.765W

Elev: 33

StdP: 14.68

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.4	18.5	N/A	N/A	N/A	N/A	N/A	N/A	31.1	30.1	27.3	32.7	14.2	20	0.467

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.3	88.2	N/A	85.7	N/A	83.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.2	20

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	(o)	(p)
27.4	23.5	20.0	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)	(r)
			DB	10.8	93.4	4.2	2.6	7.8	95.3	5.4	96.8	3.0	98.3	0.0	100.2	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	55.1	32.9	34.7	40.6	51.9	61.1	70.3	76.3	75.3	69.5	59.4	48.2	39.7
	DBStd	16.54	8.95	7.50	7.50	6.35	6.36	5.64	4.14	3.95	5.37	6.74	7.40	7.81
	HDD50	1771	530	430	302	50	1	0	0	0	0	7	120	331
	HDD65	4678	994	848	755	397	157	18	0	1	18	200	505	785
	CDD50	3629	1	2	12	105	345	608	816	784	584	297	65	10
	CDD65	1061	0	0	0	3	35	175	351	320	152	25	0	0
	CDH74	6334	0	0	0	24	154	919	2481	1989	678	88	1	0
	CDH80	1449	0	0	0	3	24	201	663	433	106	19	0	0
Wind	WSAvg	8.5	10.3	10.3	10.3	8.8	7.5	7.1	6.8	6.4	6.9	8.4	9.5	9.7
Precipitation	PrecAvg	41.0	3.2	2.7	3.8	3.8	3.9	3.6	3.7	3.6	3.4	2.8	3.3	3.4
	PrecMax	59.1	8.3	4.9	8.2	9.5	10.7	9.2	8.5	8.3	9.6	6.6	9.5	6.7
	PrecMin	25.4	0.5	0.5	0.9	1.4	0.6	0.2	0.6	0.4	0.9	0.4	0.3	0.6
	PrecStd	7.4	2.0	1.2	1.6	1.7	2.0	2.2	2.0	2.1	2.0	1.5	2.2	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.0	58.6	64.7	77.6	83.1	89.3	92.6	90.5	86.8	82.6	67.6	61.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	53.1	51.9	59.0	70.0	78.2	85.1	88.9	86.9	83.1	75.6	63.2	57.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	49.7	48.1	54.6	65.4	74.5	81.9	86.2	84.4	80.3	71.6	61.2	54.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	45.4	44.8	50.9	61.5	71.2	79.2	83.8	82.3	77.9	68.7	59.0	51.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	11.3	11.7	12.0	13.9	13.6	12.7	12.3	11.9	12.0	11.8	11.2	10.2
		MCDBR	16.3	16.3	16.7	20.6	18.1	16.7	15.8	15.2	14.3	16.2	13.4	13.6
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDWR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.319	0.330	0.361	0.385	0.433	0.489	0.496	0.478	0.403	0.364	0.333	0.319	
	taud	2.452	2.426	2.397	2.365	2.259	2.142	2.134	2.175	2.356	2.479	2.518	2.515	
	Ebn at Noon	266	279	282	282	269	253	250	251	264	264	259	257	
	Edh at Noon	25	30	34	37	43	48	48	45	35	28	23	22	
All-Sky Solar Radiation	RadAvg	589	874	1191	1527	1699	1865	1899	1675	1378	954	666	502	
	RadStd	48	87	99	152	172	173	95	108	125	94	58	47	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (61 neighbors)	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+209	+119

Nomenclature: See separate page