

LEWES HARBOR, DE, USA

WMO: 997281

Lat: 38.7834N

Lon: 75.1191W

Elev: 10

StdP: 101.20

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -8.1	(c) -5.7	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 17.5	(k) -2.9	(l) 16.0	(m) -2.8	(n) 7.7	(o) 330	(p) 0.500

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 7.0	(c) 32.8	(d) N/A	(e) 31.3	(f) N/A	(g) 29.9	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 4.3	(p) 230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 15.6	(b) 13.6	(c) 11.7	(d) DB	(e) -11.1	(f) 35.1	(g) 2.4	(h) 1.7	(i) -12.8	(j) 36.3	(k) -14.2	(l) 37.3	(m) -15.5	(n) 38.2	(o) -17.3	(p) 39.4	(q) N/A
(a) 15.6	(b) 13.6	(c) 11.7	(d) WB	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A	(q) N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	14.3	2.8	3.4	6.7	12.8	17.9	22.9	25.6	24.6	21.4	16.2	10.0	6.3
	DBStd	8.99	5.53	4.96	4.59	4.63	4.23	3.33	2.48	2.31	2.94	3.87	4.37	4.91
	HDD10.0	762	232	194	123	20	0	0	0	0	0	3	53	137
	HDD18.3	2220	481	419	359	178	62	3	0	7	88	251	373	
	CDD10.0	2327	9	8	23	104	245	388	483	454	342	195	53	23
	CDD18.3	742	0	0	0	12	48	141	225	196	99	21	1	1
	CDH23.3	4808	0	0	2	79	284	923	1795	1249	411	64	0	0
	CDH26.7	1411	0	0	0	23	72	299	594	327	86	11	0	0
(14) Wind	WSAvg	4.9	5.7	5.9	5.8	5.4	4.4	4.1	3.4	3.4	4.3	5.1	5.5	5.4
(15) Precipitation	PrecAvg	1151	90	70	111	85	88	95	112	106	104	97	87	91
	PrecMax	1469	159	150	198	139	172	233	211	214	188	204	167	200
	PrecMin	986	26	24	8	36	25	43	43	18	11	5	16	45
	PrecStd	138	34	33	46	27	42	45	45	48	50	55	47	40
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.5	20.5	22.8	29.9	31.2	34.4	35.1	34.4	31.3	27.9	22.4	21.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	16.7	17.0	19.6	25.4	28.7	31.9	33.0	31.9	29.0	25.1	19.8	19.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	14.4	13.9	16.5	22.6	26.6	30.0	31.5	30.1	27.2	23.3	17.9	16.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	11.2	10.5	13.8	20.0	24.3	28.0	29.9	28.3	25.6	21.7	16.1	13.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	MDBR		6.9	6.9	6.9	7.6	7.4	6.9	7.0	5.8	5.6	6.4	6.4	6.5
	5% DB	MCDBR	11.3	11.7	12.4	11.6	10.6	10.1	9.2	8.8	8.1	8.2	8.5	9.6
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub		0.317	0.320	0.359	0.392	0.442	0.488	0.505	0.501	0.414	0.362	0.329	0.316
	taud		2.499	2.493	2.415	2.345	2.239	2.154	2.123	2.119	2.342	2.490	2.530	2.539
	Ebn at Noon		860	908	899	885	844	802	784	776	831	848	840	836
	Edh at Noon		78	89	107	122	138	151	154	151	114	89	76	71
(44) All-Sky Solar Radiation	RadAvg		2.09	2.94	3.97	5.09	5.74	6.28	6.17	5.50	4.49	3.33	2.38	1.84
	RadStd		0.18	0.31	0.33	0.38	0.64	0.49	0.30	0.36	0.45	0.33	0.22	0.18

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB		1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (58 neighbors)	+0.47	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+139	+82

Nomenclature: See separate page