

EASTPORT HARBOR, ME, USA

WMO: 997287

Lat: 44.9046N

Lon: 66.9829W

Elev: 33

StdP: 14.68

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.7	6.8	N/A	N/A	N/A	N/A	N/A	N/A	37.7	37.1	33.8	37.5	10.1	290	0.639

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.3	75.8	N/A	72.2	N/A	69.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.7	180

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
29.9	25.5	21.2	-3.2	85.5	4.1	4.6	-6.1	88.8	-8.5	91.5	-10.8	94.1	-13.8	97.4		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.4	24.5	24.9	32.6	41.8	48.8	55.5	60.7	61.5	58.2	50.4	41.2	31.6
	DBStd	14.58	10.64	8.99	7.55	4.75	4.50	4.26	4.18	3.22	4.44	5.75	7.80	9.26
	HDD50	3274	791	702	541	248	75	3	0	0	1	65	276	572
	HDD65	7542	1256	1122	1005	695	502	286	147	117	210	452	714	1036
	CDD50	1233	0	0	1	2	38	169	330	356	247	78	12	0
	CDD65	29	0	0	0	0	0	2	12	9	6	0	0	0
	CDH74	214	0	0	3	0	11	23	99	42	33	3	0	0
	CDH80	46	0	0	0	0	1	4	28	6	7	0	0	0
Wind	WSAvg	8.9	10.3	10.0	10.9	9.8	8.5	7.5	6.5	6.3	7.3	9.2	9.9	10.7
Precipitation	PrecAvg	41.3	3.5	2.9	3.7	3.4	3.7	3.1	2.8	2.9	3.7	3.8	4.5	3.9
	PrecMax	63.5	9.3	5.9	7.7	7.9	9.2	8.2	6.9	9.3	8.9	8.8	8.3	7.4
	PrecMin	27.9	0.4	0.6	0.6	0.7	0.7	0.7	0.7	0.2	1.4	1.3	1.7	0.7
	PrecStd	7.6	1.8	1.4	1.8	1.7	2.1	1.6	1.5	1.9	1.7	1.9	1.8	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.7	47.0	57.0	60.1	73.2	77.0	84.4	78.7	78.1	70.7	59.8	54.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	48.0	43.0	48.7	55.1	64.0	70.6	75.5	74.1	71.2	63.3	56.9	51.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	44.2	40.5	45.0	51.3	59.0	66.7	71.4	71.0	67.3	60.2	54.8	48.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	40.6	38.0	42.2	48.5	55.3	62.9	68.2	67.9	64.5	58.1	52.5	45.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Mean Daily Temperature Range	5% DB	MDBR	13.5	12.6	11.4	10.8	11.4	12.1	13.6	12.3	11.3	9.9	10.2	12.0
		MCDBR	16.7	14.7	14.6	15.8	18.9	20.1	19.9	17.8	15.6	12.7	12.8	15.2
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.293	0.299	0.327	0.354	0.374	0.412	0.428	0.402	0.367	0.334	0.316	0.299	
	taud	2.471	2.476	2.452	2.419	2.410	2.326	2.304	2.378	2.442	2.529	2.536	2.485	
	Ebn at Noon	264	284	289	288	284	272	266	269	271	267	253	249	
	Edh at Noon	22	26	31	35	36	39	40	36	31	25	21	20	
All-Sky Solar Radiation	RadAvg	464	745	1127	1405	1597	1742	1785	1590	1298	828	487	362	
	RadStd	41	62	79	134	192	151	137	102	88	80	49	35	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (26 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	+0.77	N/A	N/A	+92	N/A

Nomenclature: See separate page