

EASTPORT HARBOR, ME, USA

WMO: 997287

Lat: 44.9046N

Lon: 66.9829W

Elev: 10

StdP: 101.20

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -16.8	(c) -14.0	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 16.9	(k) 2.9	(l) 15.1	(m) 3.1	(n) 4.5	(o) 290	(p) 0.639

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 6.8	(c) 24.3	(d) N/A	(e) 22.3	(f) N/A	(g) 20.6	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 3.0	(p) 180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 13.3	(b) 11.4	(c) 9.5	(e) -19.5	(f) 29.7	(g) 2.3	(h) 2.6	(i) -21.2	(j) 31.5	(k) -22.5	(l) 33.0	(m) -23.8	(n) 34.5	(o) -25.4	(p) 36.3		
			DB		WB											
			N/A		N/A		N/A		N/A		N/A		N/A		N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.9	-4.2	-3.9	0.3	5.5	9.3	13.1	15.9	16.4	14.6	10.2	5.1	-0.2
	DBStd	8.10	5.91	4.99	4.19	2.64	2.50	2.37	2.32	1.79	2.46	3.19	4.34	5.15
	HDD10.0	1819	439	390	301	138	42	2	0	0	1	36	153	318
	HDD18.3	4190	698	623	558	386	279	159	82	65	117	251	397	576
	CDD10.0	685	0	0	1	1	21	94	183	198	137	43	7	0
	CDD18.3	16	0	0	0	0	0	1	7	5	3	0	0	0
	CDH23.3	119	0	0	2	0	6	13	55	23	18	2	0	0
	CDH26.7	26	0	0	0	0	1	2	16	3	4	0	0	0
(14) Wind	WSAvg	4.0	4.6	4.5	4.9	4.4	3.8	3.4	2.9	2.8	3.3	4.1	4.4	4.8
(15) Precipitation	PrecAvg	1050	88	74	93	87	93	79	72	73	95	97	114	99
	PrecMax	1613	237	150	196	201	234	208	174	236	225	224	211	189
	PrecMin	709	11	15	14	18	18	17	18	4	36	34	43	18
	PrecStd	193	46	35	46	44	53	40	38	48	44	49	45	45
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.5	8.3	13.9	15.6	22.9	25.0	29.1	26.0	25.6	21.5	15.4	12.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	8.9	6.1	9.3	12.8	17.8	21.5	24.2	23.4	21.8	17.4	13.8	10.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	6.8	4.7	7.2	10.7	15.0	19.3	21.9	21.7	19.6	15.7	12.7	9.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	4.8	3.3	5.6	9.2	12.9	17.1	20.1	20.0	18.0	14.5	11.4	7.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	5% DB	MDBR	7.5	7.0	6.3	6.0	6.3	6.7	7.5	6.8	6.3	5.5	5.7	6.7
		MCDBR	9.3	8.2	8.1	8.8	10.5	11.1	11.1	9.9	8.7	7.1	7.1	8.5
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub		0.293	0.299	0.327	0.354	0.374	0.412	0.428	0.402	0.367	0.334	0.316	0.299
	taud		2.471	2.476	2.452	2.419	2.410	2.326	2.304	2.378	2.442	2.529	2.536	2.485
	Ebn at Noon		831	895	910	908	895	858	839	849	855	841	798	784
	Edh at Noon		69	82	97	109	114	124	126	113	98	78	66	63
(44) All-Sky Solar Radiation	RadAvg		1.46	2.35	3.55	4.43	5.04	5.49	5.63	5.01	4.09	2.61	1.53	1.14
	RadStd		0.13	0.20	0.25	0.42	0.60	0.48	0.43	0.32	0.28	0.25	0.16	0.11

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (26 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.43	N/A	N/A	+51	N/A

Nomenclature: See separate page