

QUONSET POINT, RI, USA

WMO: 997288

Lat: 41.586N

Lon: 71.407W

Elev: 33

StdP: 14.68

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 11.5	(c) 15.5	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 34.5	(k) 38.7	(l) 31.8	(m) 41.6	(n) 11.1	(o) 290	(p) 0.593

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 10.2	(c) 84.1	(d) N/A	(e) 81.2	(f) N/A	(g) 79.0	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 11.1	(p) 220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 32.3	(b) 26.7	(c) 23.4	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.3	31.0	32.3	38.5	48.6	57.4	66.6	73.7	71.7	65.9	56.4	45.8	38.1
	DBStd	16.01	9.03	7.72	7.22	5.57	6.02	5.53	3.86	3.83	5.15	6.46	7.32	8.34
	HDD50	2105	589	497	361	91	6	0	0	0	0	18	166	377
	HDD65	5315	1054	917	822	493	245	45	1	1	51	275	577	834
	CDD50	2933	0	0	5	48	236	498	734	673	476	216	39	8
	CDD65	666	0	0	0	0	11	93	269	209	77	7	0	0
	CDH74	2450	0	0	0	2	37	301	1199	737	156	18	0	0
	CDH80	379	0	0	0	0	6	63	219	79	9	3	0	0
Wind	WSAvg	11.1	10.9	11.4	12.5	12.4	12.0	11.1	10.4	9.7	10.0	11.2	10.8	10.8
Precipitation	PrecAvg	46.3	3.7	3.5	4.7	4.1	3.5	3.6	3.3	3.8	4.0	3.9	3.9	4.4
	PrecMax	56.1	6.2	6.5	15.2	8.0	7.4	10.7	10.1	7.8	9.3	13.0	6.7	7.2
	PrecMin	37.1	1.7	1.8	0.3	1.5	1.1	0.0	1.0	0.8	0.8	0.4	0.7	1.3
	PrecStd	5.3	1.2	1.3	3.0	1.7	1.3	2.6	1.8	1.8	1.9	2.6	1.6	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.2	53.3	61.0	71.9	79.3	85.9	89.0	86.3	81.2	75.7	64.6	60.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	50.6	49.5	55.4	63.4	72.9	80.8	85.4	82.1	77.7	70.3	60.9	56.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	47.1	45.6	51.2	59.5	69.7	77.1	82.1	79.8	75.5	68.1	58.9	54.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	43.9	42.7	48.4	56.8	66.6	74.3	79.7	77.9	73.6	65.9	57.0	51.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	12.3	12.1	11.7	11.9	11.7	11.1	10.2	10.7	11.1	11.4	11.5	11.1
		MCDBR	15.8	14.5	14.8	15.8	16.5	15.2	13.4	12.7	11.5	11.8	12.1	13.4
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.303	0.312	0.336	0.374	0.417	0.462	0.486	0.444	0.376	0.343	0.314	0.302
	taud		2.501	2.479	2.457	2.382	2.295	2.208	2.149	2.258	2.423	2.522	2.560	2.557
	Ebn at Noon		271	286	290	284	273	260	252	260	272	271	265	263
	Edh at Noon		23	28	32	37	41	45	47	41	33	26	22	21
All-Sky Solar Radiation	RadAvg		595	873	1193	1538	1702	1862	1914	1719	1400	946	647	498
	RadStd		45	85	86	165	166	186	101	90	103	86	47	49

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47) Regional (67 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+171	+83	(47)

Nomenclature: See separate page