

QUONSET POINT, RI, USA

WMO: 997288

Lat: 41.586N

Lon: 71.407W

Elev: 10

StdP: 101.20

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -11.4	(c) -9.2	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 15.4	(k) 3.7	(l) 14.2	(m) 5.3	(n) 5.0	(o) 290	(p) 0.593

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 5.7	(c) 28.9	(d) N/A	(e) 27.3	(f) N/A	(g) 26.1	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 5.0	(p) 220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 14.5	(b) 11.9	(c) 10.5	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.3	-0.6	0.1	3.6	9.2	14.1	19.2	23.1	22.1	18.8	13.5	7.6	3.4		
	DBStd	8.89	5.01	4.29	4.01	3.09	3.35	3.07	2.14	2.13	2.86	3.59	4.07	4.64		
	HDD10.0	1169	327	276	201	51	3	0	0	0	0	10	92	209		
	HDD18.3	2953	586	509	457	274	136	25	1	1	28	153	321	463		
	CDD10.0	1629	0	0	3	27	131	277	408	374	264	120	22	4		
	CDD18.3	370	0	0	0	0	6	52	149	116	43	4	0	0		
	CDH23.3	1361	0	0	0	1	21	167	666	409	87	10	0	0		
	CDH26.7	211	0	0	0	0	3	35	122	44	5	2	0	0		
(14) Wind	WSAvg	5.0	4.9	5.1	5.6	5.5	5.4	5.0	4.7	4.3	4.5	5.0	4.8	4.8		
(15) Precipitation	PrecAvg	1176	93	88	120	105	88	91	84	96	102	99	99	111		
	PrecMax	1425	157	165	387	204	188	271	257	199	235	330	171	183		
	PrecMin	942	42	45	7	39	29	0	25	20	21	9	19	32		
	PrecStd	135	31	34	77	43	34	67	45	46	49	66	40	39		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.4	11.8	16.1	22.2	26.3	30.0	31.7	30.2	27.3	24.3	18.1	15.8		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	10.3	9.7	13.0	17.4	22.7	27.1	29.7	27.8	25.4	21.3	16.1	13.8		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	8.4	7.5	10.7	15.3	20.9	25.1	27.8	26.6	24.2	20.1	14.9	12.3		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	6.6	6.0	9.1	13.8	19.2	23.5	26.5	25.5	23.1	18.8	13.9	10.6		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	MDBR		6.8	6.7	6.5	6.6	6.5	6.1	5.7	5.9	6.2	6.4	6.4	6.1		
	5% DB	MCDBR	8.8	8.1	8.2	8.8	9.2	8.4	7.4	7.1	6.4	6.6	6.7	7.4		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.303	0.312	0.336	0.374	0.417	0.462	0.486	0.444	0.376	0.343	0.314	0.302		
	taud		2.501	2.479	2.457	2.382	2.295	2.208	2.149	2.258	2.423	2.522	2.560	2.557		
	Ebn at Noon		854	901	914	896	861	820	795	819	859	854	836	828		
	Edh at Noon		73	87	100	116	130	142	149	130	103	83	69	65		
(44) All-Sky Solar Radiation	RadAvg		1.88	2.75	3.76	4.85	5.36	5.87	6.03	5.42	4.42	2.98	2.04	1.57		
	RadStd		0.14	0.27	0.27	0.52	0.52	0.58	0.32	0.28	0.32	0.27	0.15	0.15		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (67 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+95	+46

Nomenclature: See separate page