

OREGON INLET MARINA, NC, USA

WMO: 997307

Lat: 35.7957N

Lon: 75.5482W

Elev: 10

StdP: 101.20

Time Zone: -5.00 (NAE)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -3.6	(c) -1.4	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 13.0	(k) 7.1	(l) 11.8	(m) 5.5	(n) 6.5	(o) 320	(p) 0.532

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 3.7	(c) 30.2	(d) N/A	(e) 29.4	(f) N/A	(g) 28.8	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 6.6	(p) 200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 12.2	(b) 11.1	(c) 10.1	(d) DB	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A	(q) N/A
(a) 12.2	(b) 11.1	(c) 10.1	(d) WB	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A	(q) N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.7	6.0	6.9	9.3	15.2	20.4	24.5	26.2	25.8	23.7	19.0	12.8	9.9
	DBStd	7.96	4.50	4.04	3.97	3.43	3.23	2.29	1.79	1.48	2.11	3.13	3.70	4.35
	HDD10.0	374	135	101	63	2	0	0	0	0	0	0	17	56
	HDD18.3	1565	382	320	281	103	19	0	0	0	0	31	168	261
	CDD10.0	2818	12	14	41	159	322	435	502	489	411	278	101	53
	CDD18.3	967	0	0	1	10	83	185	244	231	161	51	1	1
	CDH23.3	6772	0	0	1	5	231	1353	2313	1959	854	57	0	0
	CDH26.7	1137	0	0	0	0	10	207	511	331	78	1	0	0
(14) Wind	WSAvg	5.1	4.9	5.2	5.3	5.6	5.5	5.5	5.5	4.4	5.0	5.0	5.0	4.8
(15) Precipitation	PrecAvg	1231	98	80	94	69	81	126	144	158	128	89	64	84
	PrecMax	1768	189	165	197	188	180	239	263	297	259	209	175	151
	PrecMin	683	29	24	20	14	0	25	26	77	19	9	0	19
	PrecStd	247	48	41	49	51	54	55	60	63	64	53	46	32
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.7	18.0	21.1	24.2	28.1	31.4	31.5	30.9	29.1	26.3	21.2	19.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	15.1	15.7	18.8	22.6	26.3	29.6	30.3	29.6	28.3	24.9	20.0	18.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	13.5	14.1	16.8	21.6	25.5	28.6	29.6	29.0	27.6	23.8	18.9	17.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	12.1	12.7	15.3	20.5	24.7	27.9	28.9	28.4	26.9	22.9	17.8	15.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	5% DB	MDBR	5.3	5.7	5.3	5.4	4.4	4.0	3.7	3.8	3.3	4.2	4.7	5.1
		MCDBR	7.3	7.0	7.0	6.0	4.8	5.0	4.2	4.5	3.8	4.3	5.5	5.7
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub		0.328	0.334	0.356	0.400	0.442	0.484	0.511	0.498	0.420	0.370	0.339	0.332
	taud		2.531	2.511	2.471	2.354	2.276	2.207	2.143	2.169	2.390	2.513	2.544	2.543
	Ebn at Noon		873	909	914	885	848	809	784	786	837	857	852	843
	Edh at Noon		80	91	104	123	134	144	153	146	111	91	79	75
(44) All-Sky Solar Radiation	RadAvg		2.37	3.16	4.25	5.41	6.09	6.45	6.05	5.54	4.59	3.69	2.68	2.15
	RadStd		0.16	0.32	0.32	0.40	0.43	0.33	0.31	0.38	0.28	0.35	0.19	0.17

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (39 neighbors)	+0.43	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+159	+109

Nomenclature: See separate page